

## Ref. Certif. No.

# US-18953-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

#### SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

### **CB TEST CERTIFICATE**

Product Produit

Name and address of the applicant Nom et adresse du demandeur

Name and address of the manufacturer Nom et adresse du fabricant

Name and address of the factory Nom et adresse de l'usine

Note: When more than one factory, please report on page 2 Note: Lorsque il y plus d'une usine, veuillez utiliser la  $2^{\rm ame}$  page

Ratings and principal characteristics Valeurs nominales et caractéristiques principales

Trademark (if any) Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used Type de programme du laboratoire d'essais constructeur

Model / Type Ref. Ref. De type

Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire,, peuvent être indiqués sur la 2<sup>ème</sup> page

A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la

As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body Ce Certificat d'essai OC est établi par l'Organisme **National de Certification** 



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA For full legal entity names see www.ul.com/ncbnames

Date: 2012-05-08

Signature:

Jolanta M. Wroblewska

Switching Power Supplies

XP POWER LLC SUITE 150 1241 E DYER RD SANTA ANA CA 92705, USA

XP POWER LLC SUITE 150 1241 E DYER RD SANTA ANA CA 92705, USA

XP POWER LLC 990 BENECIA AVE SUNNYVALE CA 94085 USA

Additional Information on page 2

Model CCH400PSXX Input: 100-240 Vac, 50/60 Hz, 6.5 A Model CCH600PSXX Input: 100-240 Vac, 50/60 Hz, 8.9 A Output: See Model Differences for ratings.



CCH400PSXX, CCH600PSXX See Page 2

Additionally evaluated to EN 60950-1:2006/ A11:2009/ A1:2010/ A12:2011; National Differences specified in the CB Test Report.

IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1

E139109-A90-CB-1 issued on 2012-05-07

Ref. Certif. No.



US-18953-UL

CCH400PSXX,CCH600PSXX (where XX = can be any number between 12 to 48 designating the output voltage)

Factories: XP POWER (KUNSHAN) LTD 230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN JIANGSU 215321 CHINA

Additional information (if necessary) Information complémentaire (si nécessaire)



 $\boxtimes$ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA 

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-05-08

folaska fr. hove Signature:

Jolanta M. Wroblewska



Test Report issued under the responsibility of:



TEST REPORT IEC 60950-1 Information technology equipment - Safety - Part 1: General requirements			
Report Reference No	E139109-A90-CB-1		
Date of issue:	2012-05-07		
Total number of pages:	90		
CB Testing Laboratory	UL San Jose		
Address	455 E. Trimble Rd., San Jose, CA, 95131-1230, USA		
Applicant's name			
Address	SUITE 150 1241 E DYER RD		
	SANTA ANA CA 92705		
	UNITED STATES		
Test specification:			
Standard	IEC 60950-1:2005 (2nd Edition); Am 1:2009		
Test procedure	CB Scheme		
Non-standard test method	N/A		
Test Report Form No.	IEC60950_1B		
Test Report Form originator:	SGS Fimko Ltd		
Master TRF:	2010-04		

Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description	Switching Power Supplies
Trade Mark:	
Manufacturer:	XP POWER LLC SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES
Model/Type reference:	CCH400PSXX and CCH600PSXX (where XX = can be any number between 12 to 48 designating the output voltage)
Ratings:	Model CCH400PSXX Input: 100-240 Vac, 50/60 Hz, 6.5 A
	Model CCH600PSXX Input: 100-240 Vac, 50/60 Hz, 8.9 A
	Output: See Model Differences for ratings.

Testin	g procedure and testing location:				
[] CB Testing Laboratory					
	Testing location / address				
[]	Associated CB Test Laboratory				
	Testing location / address				
	Tested by (name + signature) :				
	Approved by (name + signature) :				
[]	Testing Procedure: TMP				
	Tested by (name + signature) :				
	Approved by (+ signature):				
	Testing location / address:				
[]	Testing Procedure: WMT				
	Tested by (name + signature) :				
	Witnessed by (+ signature):				
	Approved by (+ signature)				
	Testing location / address::				
[x]	Testing Procedure: SMT				
	Tested by (name + signature) :	Rodney Reyes	Rodney Reyes		
	Approved by (+ signature):	Tac Pham	Taulan Reyes		
	Supervised by (+ signature):	Linus Park			
	Testing location / address:	XP Power LLC, 1241 E Dyer 92705 USA	Rd, Suite 150, Santa Ana, CA		
[]	Testing Procedure: RMT				
	Tested by (name + signature) :				
	Approved by (+ signature):				
	Supervised by (+ signature):				
	Testing location / address:				
1.1.4.4					
	Attachments				
National Differences (37 pages)					
Enclosures (176 pages)					
Summary Of Testing Unless otherwise indicated, all tests were conducted at XP Power LLC, 1241 E Dyer Rd, Suite 150, Santa Ana, CA 92705 USA.					
Tests performed (name of test and test clause) Testing location / Comments					

Input: Single-Phase (1.6.2)

Energy Hazard Measurements (2.1.1.5, 2.1.2, 1.2.8.10)

Capacitance Discharge (2.1.1.7)

SELV Reliability Test Including Hazardous Voltage Measurements (2.2.2, 2.2.3, 2.2.4, Part 22 6.1)

Limited Current Circuit Measurement (2.4.1, 2.4.2)

Protective Bonding I (2.6.3.4, 2.6.1).7)

Humidity (2.9.1, 2.9.2, 5.2.2)

Determination of Working Voltage; Working Voltage Measurement (2.10.2)

Thin Sheet Material (2.10.5.9, 2.10.5.10, 2.10.5.6)

Transformer and Wire /Insulation Electric Strength (2.10.5.13)

Heating (4.5.1, 1.4.12, 1.4.13)

Ball Pressure (4.5.5, 4.5)

Touch Current (Single-Phase; TN/TT System) (5.1, Annex D)

Electric Strength (5.2.2)

Component Failure (5.3.1, 5.3.4, 5.3.7)

Abnormal Operation (5.3.1 - 5.3.9)

Transformer Abnormal Operation (5.3.3, 5.3.7b, Annex C.1)

Power Supply Output Short-Circuit/Overload (5.3.7)

#### Summary of Compliance with National Differences:

Countries outside the CB Scheme membership may also accept this report.

List of countries addressed: AT, BE, BG, BY, CA, CH, CN, CZ, DE, DK, ES, EU, FI, FR, GB, GR, HU, IE, IL, IT, JP, KR, NL, PL, PT, RO, SE, SI, SK, UK, US

The product fulfills the requirements of: CSA C22.2 No. 60950-1-07 + A1:2011, , EN 60950-1:2006 + A1:2010 + A11:2009 + A12:2011, IEC 60950-1:2005 + A1:2009, UL 60950-1 2nd Ed. Revised 2011-12-19

## **Copy of Marking Plate**

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

MODEL NO. CCH400PS12 BETA P/N 10009404	Serial No. : Rev Level :	5
INPUT : ~ 100-240Vac 50/60Hz OUTPUT : 12V 34A V Standby : 5V 0.5A	6.5A	R CE
Model No Serial No.		- 50° * 90
www.xppower.com	Serial No. :	
	Serial No. : Rev Level :	
WWW.Xppower.com MODEL NO. CCH800P512 BETA	Rev Level :	<u>ر</u> د

Test item particulars :				
Equipment mobility	for building-in			
Connection to the mains	To be determined in the end-use product.			
Operating condition	continuous			
Access location	To be determined in the end-use product.			
Over voltage category (OVC)	OVC II			
Mains supply tolerance (%) or absolute mains supply values	+10%, -10%			
Tested for IT power systems	No			
IT testing, phase-phase voltage (V)	N/A			
Class of equipment	Class I (earthed)			
Considered current rating of protective device as part of the building installation (A)	Model CCH400PSXX: 6.5A, Model CCH600PSXX: 8.9A			
Pollution degree (PD)	PD 2			
IP protection class	IP X0			
Altitude of operation (m)	3048			
Altitude of test laboratory (m)	40			
Mass of equipment (kg)	1.5			
Possible test case verdicts:				
- test case does not apply to the test object:	N / A			
- test object does meet the requirement	P(Pass)			
- test object does not meet the requirement:	F(Fail)			
Testing:				
Date(s) of receipt of test item	2011-09-06			
Date(s) of Performance of tests	2011-11-16 to 2012-03-01			
General remarks:				
The test results presented in this report relate only to This report shall not be reproduced, except in full, wit				
"(see Enclosure #)" refers to additional information ap "(see appended table)" refers to a table appended to				
Throughout this report a point is used as the decimal	separator.			
Manufacturer's Declaration per Sub Clause 6.25 of IECEE 02:The application for obtaining a CB Test Certificate includes more than one factory and a declaration form the Manufacturer stating that the sample(s) submitted for evaluation is (are)Yes representative of the products from each factory has been provided				
When differences exist, they shall be identified in the General Product Information section.				
Name and address of Factory(ies): XP POWE 990 BENE				

Report Reference #

SUNNYVALE CA 94085 UNITED STATES

XP POWER (KUNSHAN) LTD 230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN JIANGSU 215321 CHINA

#### **GENERAL PRODUCT INFORMATION:**

#### **Report Summary**

All applicable tests according to the referenced standard(s) have been carried out.

#### **Product Description**

The product is a component AC-DC power supply for building-in, open frame type provided with a metal chassis, incorporating primary and SELV components and a baseplate for conduction cooling.

#### Model Differences

The power supplies in the series are differentiated by the output voltage and current ratings, number of turns of primary/secondary windings in the Transformer (T1 (Power)) and minor differences in the secondary circuit components.

Model CCH400PSXX Series is identical to Model CCH600PSXX Series with exception to the output ratings for their respective series.

Suffix "XX" denotes the output voltage rating.

See below for Output Ratings:

Model CCH400PS12: Output Rated: 12 Vdc, 34.0 A (400 W); Stand-by: 5 V, 0.5A Model CCH400PS24: Output Rated: 24 Vdc, 17.0 A (400 W); Stand-by: 5 V, 0.5A Model CCH400PS28: Output Rated: 28 Vdc, 14.5 A (400 W); Stand-by: 5 V, 0.5A Model CCH400PS48: Output Rated: 48 Vdc, 8.5 A (400 W); Stand-by: 5 V, 0.5A

Model CCH600PS12: Output Rated: 12 Vdc, 50.0 A (600 W); Stand-by: 5 V, 0.5A Model CCH600PS24: Output Rated: 24 Vdc, 25.0 A (600 W); Stand-by: 5 V, 0.5A Model CCH600PS28: Output Rated: 28 Vdc, 21.5 A (600 W); Stand-by: 5 V, 0.5A Model CCH600PS48: Output Rated: 48 Vdc, 12.5 A (600 W); Stand-by: 5 V, 0.5A

#### Additional Information

The clearance distances have additionally been assessed for suitability up to 3048 m elevation (1.15 correction factor as per IEC 60664-1, Table A2).

Power supply is designed with a base plate that acts as a heat sink to all the power supply components; as a result, the actual component temperatures are based upon the relative temperature rise from the base plate temperature. Based upon this design, the base plate temperature should not exceed 85°C to insure

component temperatures do not exceed their limits.

Nameplate Marking label provided is considered representative of all models.

**Technical Considerations** 

- The product is intended for use on the following power systems: TN
- The equipment disconnect device is considered to be: determined in the end-product.,
- The product was investigated to the following additional standards: EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 (which includes all European national differences, including those specified in this test report).

#### **Engineering Conditions of Acceptability**

When installed in an end-product, consideration must be given to the following:

- Consideration to repeating Heating and Touch Current Tests should be given in the end-product evaluation. --
- Means of disconnection to be provided as part of the end-product. --
- Components within the power supply are heat sinked to the base plate of the power supply. The base plate temperature should not exceed 85°C as part of the end product evaluation. --
- The maximum continuous power supply output (Watts) relied on the base plate temperature not exceeding 85°C. End product shall determine appropriate heat sink size, maximum recommended ambient temperature, and output load to prevent the base plate temperature from exceeding 85°C. --
- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-Earthed Dead Metal: 243 Vrms, 366 Vpk, Primary-SELV: 353 Vrms, 631 Vpk --
- The following secondary output circuits are SELV: All outputs --
- The following secondary output circuits are at hazardous energy levels: All outputs --
- The power supply terminals and/or connectors are: Not investigated for field wiring --
- The maximum investigated branch circuit rating is: 20 A --
- The investigated Pollution Degree is: 2 --
- Proper bonding to the end-product main protective earthing termination is: Required --

- An investigation of the protective bonding terminals has: Not been conducted --
- The following input terminals/connectors must be connected to the end-product supply neutral: CON3 --
- The following end-product enclosures are required: Mechanical, , Fire, and , Electrical --
- The following Production-Line tests are conducted for this product: Earthing Continuity, , Electric Strength --
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): Platform: L1-L5, L7, L8, L12, L13, PFC Inductor, T1 and T3 (Class F, 155°C); Control Board: L15 and T1 (Class F, 155°C) --
- The following components require special consideration during end-product Thermal (Heating) tests due to the indicated maximum temperature measurements during component-level testing: Power Supply Baseplate (85°C) --

Abbreviations used in the report:					
- normal condition	N.C.	- single fault condition	.S.F.C		
- operational insulation	OP	- basic insulation	BI		
- basic insulation between parts of opposite polarity:	BOP	- supplementary insulation	. SI		
- double insulation	. DI	- reinforced insulation	. RI		
Indicate used abbreviations (if any)					