

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME****CB TEST CERTIFICATE**

Product	Switching Power Supply
Name and address of the applicant	XP POWER L L C 15641 RED HILL AVE, SUITE 100 TUSTIN CA 92780 UNITED STATES
Name and address of the manufacturer	XP POWER L L C 15641 RED HILL AVE, SUITE 100 TUSTIN CA 92780 UNITED STATES
Name and address of the factory	XP POWER (KUNSHAN) LTD 230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN JIANGSU 215300 CHINA <input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Page 2
Trademark (if any)	
Type of Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	102141-XX, 102147-XX, 102149-XX, 102150-XX See Page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN 62368-1:2014 / A11:2017; National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	E139109-A6074-CB-1 issued on 2019-02-18

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-02-21

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-33264-UL

Model Details:

102141-XX,102147-XX,102149-XX,102150-XX

Where X is any alphanumeric character or blank. "-" is optional.

Factories:

XP POWER (VIETNAM) CO LTD

LOT D - 4Q - CN MY PHUOC 3 INDUSTRIAL PARK BEN CAT DISTRICT BINH DUONG BINH DUONG VIETNAM

XP POWER PLC

16 HOESHOE PARK PANGBOURNE RG8 7JW UNITED KINGDOM

XP POWER LIMITED

LIPO BLDG, #05-01 621 ALJUNIED RD SINGAPORE 389834 SINGAPORE

XP POWER LLC

990 BENECIA AVE SUNNYVALE CA 94085 UNITED STATES

Ratings:

Model 102141-XX, 102147-XX and 102150-XX Series:

Input: 100-240V~, 10A 50/60Hz

Model 102149-XX Series:

Input: 100-240V~, 6.3A 50/60Hz

Output ratings are optional:

Model 102147-XX and 102150-XX:

Output: 12Vdc66.6A

(Maximum Output Power is 800W at 40°C)

Models 102149-XX and 102141-XX:

Output: 12Vdc33.3A

(Maximum Output Power is 400W at 40°C)

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-02-21

Signature:

Jolanta M. Wroblewska