

IEC SYSTEM FOR CONFORMITY TESTING AND  
CERTIFICATION OF ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ESSAIS DE CONFORMITE ET DE CERTIFICATION  
DES EQUIPEMENTS ELECTRIQUES (IECEE)  
METHODE OC

## CB TEST CERTIFICATE

## CERTIFICAT D'ESSAI OC

Product  
Produit

Name and address of the applicant  
Nom et adresse du demandeur

Name and address of the manufacturer  
Nom et adresse du fabricant

Name and address of the factory  
Nom et adresse de l'usine

Rating and principal characteristics  
Valeurs nominales et caractéristiques principales

Trademark (if any)  
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

Model / Type Ref.  
Ref. de type

Additional information (if necessary)  
Information complémentaire (si nécessaire)

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

as shown in the Test Report Ref. No.  
which forms part of this Certificate  
comme indiqué dans le Rapport d'essais numéro  
de référence qui constitue partie de ce Certificat

Power Rack

XP POWER INC  
SUITE 150  
1241 E DYER RD  
SANTA ANA CA 92705, USA

XP POWER INC  
SUITE 150  
1241 E DYER RD  
SANTA ANA CA 92705, USA

1. XP POWER INC  
990 BENEZIA AVE SUNNYVALE CA 94085, USA

2. XP POWER (KUNSHAN) LTD  
230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN  
JIANGSU 215321, CHINA

Input Rated:  
100-240 Vac, 50/60 Hz, max. 12 A per cord.  
Output Model Rating: See model differences for details.



N/A

GFR1K5RACK-0X (where X can be any number from 1 to 9)

The CB Test Report comprises 7 enclosures. The CB Certificate and Test Report  
were amended on June 14, 2010 to add alternate components.

### IEC 60950-1 (2005) Second Edition

Additionally evaluated to EN60950-1 (2006) with Am. 11 (2009) to include Group  
and National Differences for European countries; other National Differences also  
specified in the CB Test Report.

E139109-A30-CB-1

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



**Underwriters  
Laboratories**

Underwriters Laboratories Inc. / GMA Certification Department, US  
333 Pfingsten Road, Northbrook, IL 60062-2096  
United States of America  
TEL INT\* +1 847 664 3008, FAX INT\* +1 847 313 3008  
email: jolanta.m.wroblewska@us.ul.com

Date: Issued: 2010 March 2  
Amended: 2010 June 14 (Am. 1)

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

CA/9813/CSA

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product  
Produit

Component Power Supply

Name and address of the applicant  
Nom et adresse du demandeur

XP Power, Inc.  
1590 S Sinclair Street, Anaheim, CA 92806, USA

Name and address of the manufacturer  
Nom et adresse du fabricant

Same as applicant.

Name and address of the factory  
Nom et adresse de l'usine

Additional Information on page 2

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Input: 100-240 Vac, 50/60Hz, 16.5A

Additional Information on page 2

Trademark (if any)  
Marque de fabrique (si elle existe)



Model / Type Ref.  
Ref. De type

GFR1K5PSXX (where XX can be 12, 24, 48 or 56 designating the output voltage)

Additional information (if necessary may also be reported on page 2)  
Les informations complémentaires (si nécessaire,, peuvent être indiqués sur la 2<sup>ème</sup> page

Prepared under SMT procedure (SMT-042)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with  
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60950-1:2005 (2<sup>nd</sup> Edition) including AT, CA, DE, DK, FI, FR, GB, IT, JP, KR, NL, NO, PL, SE, SI, US and Common Modifications per CB Bulletin 112A (Dec 2006); EN 60950-1:2006

As shown in the Test Report Ref. No. which forms part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

CB 155548-2035526

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CSA International  
178 Rexdale Boulevard  
Toronto, ON M9W 1R3

Date: July 2, 2008

Signature: Tiki Wong, P.Eng



Ref. Certif. No.

CA/9813/CSA

Output Ratings

Model	V1-Output			V-standby	
	Vdc	Low-V (100-180 Vac Input)	High-V (180-240 Vac Input)	Vdc	A
GFR1K5PS12	12	100 A; 1200 W max		5	1
GFR1K5PS24	24	50 A; 1200 W max	62.5 A; 1500 W max	5	1
GFR1K5PS48	48	25 A; 1200 W max	31 A; 1500 W max	5	1
GFR1K5PS56	56	22 A; 1200 W max	27 A; 1500 W max	5	1

Name and address of the factory

Nom et adresse de l'usine

- F1 XP POWER INC  
1590 S SINCLAIR ST  
ANAHEIM, CA 92806, USA
- F2 XP POWER INC  
990 BENECIA AVE, UNIT 25  
SUNNYVALE, CA 94085, USA
- F3 UNIT 25, ZONE 37  
BAO'AN, SHENZHEN,  
GUANGDONG 518000,  
P.R. CHINA
- F4 JU-YUAN INDUSTRIAL PARK, TANG – WEI  
FU-YONG TOWN, BAO'AN, SHENZHEN,  
GUANGDONG 518103  
P.R. CHINA
- F5 230 BIN JIANG SOUTH ROAD  
ZHANG PU TOWN, KUNSHAN CITY  
JIANGSU PROVINCE, 215321  
P.R. CHINA

Additional information (if necessary)  
Information complémentaire (si nécessaire)

Date: July 2, 2008

Signature: Tiki Wong, P.Eng



Test Report issued under the responsibility of:




CSA INTERNATIONAL

<b>TEST REPORT</b>	
<b>IEC 60950-1: 2005 (2nd Edition) and/or EN 60950-1:2006</b>	
<b>Information technology equipment – Safety –</b>	
<b>Part 1: General requirements</b>	
Report Reference No.....	CB155548-2035526
Date of issue.....	June 25, 2008
Total number of pages.....	48
<b>CB/CCA Testing Laboratory</b> .....	CSA International
Address.....	13799 Commerce Parkway, Richmond (Vancouver), B.C. V6V 2N9 Canada
<b>Applicant's name</b> .....	XP Power, Inc.
Address.....	1590 S Sinclair St., Anaheim, CA 92806, USA
<b>Manufacturer's name</b> .....	XP Power, Inc.
Address.....	1590 S Sinclair St., Anaheim, CA 92806, USA
<b>Factory's name</b> .....	XP Power, Inc.
Address.....	1590 S Sinclair St., Anaheim, CA 92806, USA
<b>Test specification:</b>	
Standard .....	<input checked="" type="checkbox"/> IEC 60950-1:2005 (2nd Edition) and/or <input checked="" type="checkbox"/> EN 60950-1:2006
Test procedure .....	CB/CCA, National Deviations: AT, CA, DE, DK, FI, FR, GB, IT, JP, KR, NL, NO, PL, SE, SI, US and Common Modifications per CB Bulletin 112A (Dec 2006)
Non-standard test method.....	N/A
<b>Test Report Form No.</b> .....	IECEN60950_1C
Test Report Form(s) Originator .....	SGS Fimko Ltd
Master TRF.....	Dated 2007-06
<b>Copyright © 2007 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
<b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
If this Test Report Form is used by non-CCA members, the CIG logo and the reference to the CCA Procedure shall be removed.	
<b>This report is not valid as a CCA Test Report unless signed by an approved CCA Testing Laboratory and appended to a CCA Test Certificate issued by an NCB in accordance with CCA</b>	





TRF No. IECEN60950\_1C

2035526\_cbrep.doc\1\dw

<b>Test item description</b> ..... :	Component AC-DC Power Supply
Trade Mark .....	
Manufacturer .....	XP Power
Model/Type reference..... :	GFR1K5PSXX (where XX can be 12, 24, 48 or 56 designating the output voltage)
Ratings..... :	Input: 100-240 V ac, 50/60Hz, 16.5A

Outputs:

Model	V1-Output		V-standby		
	V dc	Low-V (100-180 V ac Input)	High-V (180-240 V ac Input)	V dc	A
GFR1K5PS12	12	100 A; 1200 W max		5	1
GFR1K5PS24	24	50 A; 1200 W max	62.5 A; 1500 W max	5	1
GFR1K5PS48	48	25 A; 1200 W max	31 A; 1500 W max	5	1
GFR1K5PS56	56	22 A; 1200 W max	27 A; 1500 W max	5	1

<b>Testing procedure and testing location:</b>	
<input type="checkbox"/> <b>CB/CCA Testing Laboratory:</b>	CSA International
Testing location/ address .....	13799 Commerce Parkway, Richmond (Vancouver), B.C. V6V 2N9 Canada
<input type="checkbox"/> <b>Associated CB Laboratory:</b>	
Testing location/ address .....	
Tested by (name + signature).....:	
Approved by (+ signature).....:	Shane Stevenson 
<input type="checkbox"/> Testing procedure: TMP	
Tested by (name + signature).....:	
Approved by (+ signature).....:	
Testing location/ address .....	
<input type="checkbox"/> Testing procedure: WMT	
Tested by (name + signature).....:	
Witnessed by (+ signature).....:	
Approved by (+ signature).....:	
Testing location/ address .....	
<input checked="" type="checkbox"/> Testing procedure: SMT	
Tested by (name + signature).....:	Rodney Reyes 
Approved by (+ signature).....:	Tac Pham 
Supervised by (+ signature).....:	Eugen Velea 
Testing location/ address .....	XP Power, Inc.; 1590 S Sinclair St., Anaheim, CA 92806, USA
<input type="checkbox"/> Testing procedure: RMT	
Tested by (name + signature).....:	
Approved by (+ signature).....:	
Supervised by (+ signature).....:	
Testing location/ address .....	

### ***CB Report Contents***

<i><b>CB Report</b></i>	<i>48 pages</i>
<i><b>Cover Pages</b></i>	<i>Page 1 to 3</i>
<i><b>Contents</b></i>	<i>Page 4</i>
<i><b>Report Revision Record</b></i>	<i>Page 5</i>
<i><b>Summary of testing and Summary of compliance with National Differences</b></i>	<i>Page 6</i>
<i><b>Copy of marking plate</b></i>	<i>Page 7</i>
<i><b>Test item particulars</b></i>	<i>Page 8</i>
<i><b>General product information and Conditions of Acceptability</b></i>	<i>Page 9</i>
<i><b>Report Check List</b></i>	<i>Page 11 to 48</i>

<i><b>Appendices</b></i>		
<i><b>1</b></i>	<i><b>National Deviations and Group Differences</b></i>	<i>36 pages</i>

<i><b>Attachments</b></i>		
<i><b>1</b></i>	<i><b>Enclosure Details and List of Critical Components</b></i>	<i>4 pages</i>
<i><b>2</b></i>	<i><b>Photographs</b></i>	<i>11 pages</i>
<i><b>3</b></i>	<i><b>Schematic Diagrams and Printed Wiring Board Drawings</b></i>	<i>17 pages</i>
<i><b>4</b></i>	<i><b>Transformer and Inductor Specifications/Drawings</b></i>	<i>39 pages</i>
<i><b>5</b></i>	<i><b>Technical Specifications</b></i>	<i>5 pages</i>
<i><b>6</b></i>	<i><b>Test Data</b></i>	<i>39 pages</i>



## **Report Revision Record**

***Edition 1:*** June 25, 2008; CSA Application No. CB 155548-2035526 (Vancouver Office)  
Issued by Eugen Velea; Reviewed by Shane Stevenson.  
CB Certificate CA/9813/CSA issued July 2, 2008



**Summary of testing:**

**Tests performed (name of test and test clause):**

Tests performed on	
Model	Manufacturer's Serial No (or Prototype Control No) of equipment tested
GFR1K5PS12	GFR1K5PS1208-01
GFR1K5PS24	GFR1K5PS2408-01
GFR1K5PS48	GFR1K5PS4808-01
GFR1K5PS56	GFR1K5PS5608-01

**Testing location:**

















XP Power, Inc.; 1590 S Sinclair St., Anaheim, CA 92806, USA

Clause	Name of Test
1.6.2	Power Interface (Input) Test
2.1.1.5	Energy Hazard Measurement (20 Joules and 240 VA)
2.1.1.7	Discharge of Capacitors
2.2	SELV (Single Fault Simulation)
2.6.3.4	Protective Earthing Resistance
2.10	Creepage/Clearance Measurements
4.5.1	Heating Test
5.1	Touch and Protective Conductor Current
5.2	Electrical Strength Test
5.3	Abnormal (component failure)
5.3.3	Transformer Test (see Annex C)
5.3.7	Overload/Short Circuit Test (Power Supply Outputs)
Annex C	Transformer (Overload)

**Summary of compliance with National Differences:**

Refer to App.1

Copy of marking plate:

 <p> <b>XP Power</b>  <a href="http://www.xppower.com">www.xppower.com</a>            MODEL NO. GFR1K5PS12            SERIAL NO. A0808001              CUSTOMER P/N            P/N 10005147 B              INPUT ~ 100 - 240VAC 50/60Hz 16.5A            OUTPUT : 12V = 100A         </p> 	 <p> <b>XP Power</b>  <a href="http://www.xppower.com">www.xppower.com</a>            MODEL NO. GFR1K5PS24            SERIAL NO. A0808001              CUSTOMER P/N            P/N 10006282 B              INPUT ~ 100 - 240VAC 50/60Hz 16.5A            OUTPUT : 24V = 62.5A         </p> 
 <p> <b>XP Power</b>  <a href="http://www.xppower.com">www.xppower.com</a>            MODEL NO. GFR1K5PS48            SERIAL NO. A0822003              CUSTOMER P/N            P/N 10006284 A              INPUT ~ 100 - 240VAC 50/60Hz 16.5A            OUTPUT : 48V = 31A         </p> 	 <p> <b>XP Power</b>  <a href="http://www.xppower.com">www.xppower.com</a>            MODEL NO. GFR1K5PS56            SERIAL NO. A0822003              CUSTOMER P/N            P/N 10007351 A              INPUT ~ 100 - 240VAC 50/60Hz 16.5A            OUTPUT : 56V = 27A         </p> 

<b>Test item particulars</b> :	
Equipment mobility .....	for building-in
Connection to the mains .....	To be determined in the end system
Operating condition .....	Continuous
Access location .....	To be determined in the end system
Over voltage category (OVC) .....	OVC II
Mains supply tolerance (%) or absolute mains supply values .....	+6%; -10%
Tested for IT power systems .....	No
IT testing, phase-phase voltage (V) .....	N/A
Class of equipment .....	Class I
Considered current rating (A) .....	20 A (branch circuit)
Pollution degree (PD) .....	PD 2
IP protection class .....	IPX0
Altitude during operation (m) .....	3000
Altitude of test laboratory (m) .....	N/A
Mass of equipment (kg) .....	3 Kg
<b>Possible test case verdicts:</b>	
- test case does not apply to the test object.....	N/A
- test object does meet the requirement .....	P (Pass)
- test object does not meet the requirement .....	F (Fail)
<b>Testing</b> .....	
Date of receipt of test item.....	Apr 18, 2008
Date(s) of performance of tests.....	June 18, 2008 (evaluation completion)
<b>General remarks:</b>	
<p>The test results presented in this report relate only to the object tested.  This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.  "(See Enclosure #)" refers to additional information appended to the report.  "(See appended table)" refers to a table appended to the report.</p> <p><b>Note: This TRF includes EN Group Differences together with National Differences and Special National Conditions, if any. All Differences are located in the Appendix to the main body of this TRF.</b></p> <p>Throughout this report a comma (point) is used as the decimal separator.</p>	

**General product information:**

The subject model is a component type AC-DC power supply, provided with an overall metal enclosure, containing components operating at hazardous and SELV voltages.

The main PCB is fastened to the chassis bottom by multiple machine screws; an insulating foil is installed between PWB and chassis, wrapped around the board assembly, covering the sides and extending over the top. The control PWB is mounted vertically on the side of the main PWB and secured by multi-pin soldering.

The unit is provided with 3 LED status indicators and 2 cooling fans mounted internally behind the front panel acting as fan guard.

Input/output connector is soldered directly to the PWB and divided into two sections, one containing the primary inputs for AC mains and Protective Earth, the other containing the SELV output pins.

For additional construction details refer to Attachments.

**Conditions of Acceptability**

1. The power supply is to be installed only by trained service personnel, according to manufacturer installation instructions provided with each unit.
2. Installation instructions and equipment markings related to safety shall be provided in a language acceptable in the country in which the equipment is to be installed.
3. Evaluated as Class I (earthed equipment). Reliable earth connection shall be provided in the end use installation.
4. Suitability of the equipment enclosure as a fire enclosure is to be determined in the end use installation.
5. Maximum temperatures have been evaluated based on the temperature derating curves specified by the manufacturer and are comprised between 50 °C and 70 °C, with 50% derating for the higher limit (refer to Att. 5). Temperature tests shall be considered for the specific installation conditions in the end system.
6. Suitable disconnect device is to be provided in the end system.
7. Input/output connector is not acceptable for field connections; it is only intended for connection to mating connector of internal wiring inside the end system.
8. Measurement for Radio Frequency interference has not been done during this evaluation. Compliance with the CISPR requirements is to be determined by the Recognizing NCB.