

US-22101-A1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product Produit

Name and address of the applicant Nom et adresse du demandeur

Name and address of the manufacturer Nom et adresse du fabricant

Name and address of the factory Nom et adresse de l'usine

Note: When more than one factory, please report on page 2 Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used Type de programme du laboratoire d'essais constructeur

Model / Type Ref. Ref. De type

Additional information (if necessary may also be reported on page 2)

Les informations complémentaires (si nécessaire,, peuvent être indiqués sur la 2ème page

A sample of the product was tested and found to be in conformity with

Un échantillon de ce produit a été essayé et a été considéré conforme à la

As shown in the Test Report Ref. No. which forms part of this Certificate

Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

CERTIFICAT D'ESSAI OC

Switching Power Supplies

XP POWER L L C SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES

XP POWER L L C SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES

XP POWER LLC 990 BENECIA AVE SUNNYVALE CA 94085 UNITED STATES

Additional Information on page 2
Input: 100-277 Vac, 50/60 Hz, 9 A
Output: See test report for details.



HHP650PSXX See Page 2

Additionally evaluated to EN 60950-1:2006/A11:2009/A1:2010/A12:2011. National Differences specified in the CB Test Report.

Additional Information on page 2 IEC 60950-1(ed.2); IEC 60950-1(ed.2)

E139109-A127-CB-1 issued on 2014-02-18

This CB Test Certificate is issued by the National Certification Body Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



Date: 2014-02-18

Original Issue Date: 2013-08-19

Signature:

UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Jolanta M. Wroblewska



US-22101-A1-UL

Model Details:

HHP650PSXX (where XX = represents the output voltage between 12-48)

Factories:

XP POWER (S) PTE LTD

LIPO BLDG, #05-01 621 ALJUNIED RD SINGAPORE 389834

SINGAPORE

XP POWER (KUNSHAN) LTD

230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN JIANGSU 215300

CHINA

Additional Information:

The original report was modified to include the following changes/additions:

Electric Strength Test conducted at higher test voltage per XP Power specifications.

Additional information (if necessary) Information complémentaire (si nécessaire)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2014-02-18

Original Issue Date: 2013-08-19

Signature:

Jolanta M. Wroblewska

Issue Date: 2013-08-19 Page 1 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18



Test Report issued under the responsibility of:



TEST REPORT IEC 60950-1

Information technology equipment - Safety - Part 1: General requirements

Report Reference No E139109-A127-CB-1

Date of issue 2013-08-19

Total number of pages 9

CB Testing Laboratory: UL San Jose

Address 455 E. Trimble Rd., San Jose, CA, 95131-1230, USA

Applicant's name XP POWER L L C

SUITE 150 Address 1241 E DYER RD

SANTA ANA CA 92705 UNITED STATES

Test specification:

Standard: IEC 60950-1:2005 (2nd Edition); Am 1:2009

Test procedure: CB Scheme

Non-standard test method: N/A

Test Report Form No. IEC60950_1C
Test Report Form originator: SGS Fimko Ltd

Master TRF 2012-08

Copyright @ 2012 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Issue Date: 2013-08-19 Page 2 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

Test item description: Switching Power Supplies

Trade Mark:

Manufacturer: XP POWER LLC

SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES

Model/Type reference HHP650PSXX (where XX = represents the output voltage between

12-48)

Ratings: Input: 100-277 Vac, 50/60 Hz, 9 A

Output: See Model Differences.

Issue Date: 2013-08-19 Page 3 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

Testing procedure and testing location:						
[]	CB Testing Laboratory					
	Testing location / address::					
[]	Associated CB Test Laboratory					
	Testing location / address:					
	Tested by (name + signature):					
	Approved by (name + signature) :					
[]	Testing Procedure: TMP					
	Tested by (name + signature):					
	Approved by (+ signature):					
	Testing location / address::					
[]	Testing Procedure: WMT					
	Tested by (name + signature):					
	Witnessed by (+ signature):					
	Approved by (+ signature):					
	Testing location / address::					
[x]	Testing Procedure: SMT					
	Tested by (name + signature):	Rodney Reyes	Rodney Reyes			
	Approved by (+ signature):	Tac Pham	Tanham			
	Supervised by (+ signature)::	David E. Drewes				
	Testing location / address::	XP Power LLC, Suite 150, 124 92705 USA	1 E Dyer Rd, Santa Ana,			
[]	Testing Procedure: RMT					
	Tested by (name + signature):					
	Approved by (+ signature)::					
	Supervised by (+ signature):					
	Testing location / address::					
lict of	Attachments					
National Differences (0 pages)						
Enclosures (0 pages)						
Summary Of Testing Unless otherwise indicated, all tests were conducted at XP Power LLC, Suite 150, 1241 E Dyer Rd, Santa Ana, 92705 USA.						
Tests performed (name of test and test clause) Testing location / Comments						
Electric Strength (5.2.2)						

Issue Date: 2013-08-19 Page 4 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

Summary of Compliance with National Differences:

Countries outside the CB Scheme membership may also accept this report.

List of countries addressed: AT, BE, BG, BY, CA, CH, CZ, DE, DK, ES, EU, FI, FR, GB, GR, HU, IE, IT, JP, KR, NL, PL, PT, RO, SE, SI, SK, UA, US

The product fulfills the requirements of: CSA C22.2 No. 60950-1-07 + A1:2011, EN 60950-1:2006 + A1:2010 + A11:2009 + A12:2011, UL 60950-1 2nd Ed. Revised 2011-12-19, IEC 60950-1:2005 + A1:2009

Copy of Marking Plate - Refer to Enclosure titled Marking Plate for copy.

 Issue Date: 2013-08-19 Page 5 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

Test item particulars:

Equipment mobility for building-in

Operating condition continuous

Access location for building-in

Over voltage category (OVC) OVC II

Mains supply tolerance (%) or absolute mains supply

values +10%, -10%

Considered current rating of protective device as part

 of the building installation (A)
 20 A

 Pollution degree (PD)
 PD 2

 IP protection class
 IP X0

 Altitude of operation (m)
 5000

Altitude of test laboratory (m) less than 2000 meters

Mass of equipment (kg) 1.5

Possible test case verdicts:

Testing:

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a point is used as the decimal separator.

Manufacturer's Declaration per Sub Clause 4.2.5 of IECEE 02:

Yes

The application for obtaining a CB Test Certificate includes more than one factory and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided

When differences exist, they shall be identified in the General Product Information section.

Name and address of Factory(ies): XP POWER LLC

990 BENECIA AVE SUNNYVALE CA 94085

Issue Date: 2013-08-19 Page 6 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

UNITED STATES

XP POWER (S) PTE LTD LIPO BLDG, #05-01 621 ALJUNIED RD SINGAPORE 389834 SINGAPORE

XP POWER (KUNSHAN) LTD 230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN JIANGSU 215300 CHINA

GENERAL PRODUCT INFORMATION:

Report Summary

The original report was modified on 2014-02-18 to include the following changes/additions: Electric Strength Test conducted at higher test voltage per XP Power specifications.

Product Description

The product is a component AC-DC power supply for building-in, open frame type provided with a metal chassis, incorporating primary and SELV components. The power supply is intended for use in Class I Information Technology Equipment.

The main PWB is secured to the chassis by multiple machine screws.

Model Differences

The power supplies in the series are differentiated by the output voltage and current ratings, number of turns of primary/secondary windings in the Transformers (T302) and minor differences in the secondary circuit components.

See below for Model Ratings (up to 50°C) for Model HHP650PSXX, where XX indicated the output voltage:

Model HHP650PS12: Output Rated: 12.0 Vdc, 50A (600W) Model HHP650PS15: Output Rated: 15.0 Vdc, 40A (600W) Model HHP650PS24: Output Rated: 24.0 Vdc, 27.0 A (650W)

Model HHP650PS24 (Input: 180-277Vac): Output Rated: 24.0 Vdc, 32.4 A (780W)

Model HHP650PS28: Output Rated: 28.0 Vdc, 23.0 A (650W)

Model HHP650PS28 (Input: 180-277Vac): Output Rated: 28.0 Vdc, 27.6 A (780W)

Model HHP650PS36: Output Rated: 36.0 Vdc, 18.0 A (650W)

Model HHP650PS36 (Input: 180-277Vac): Output Rated: 36.0 Vdc, 21.6 A (780W)

Model HHP650PS48: Output Rated: 48.0 Vdc, 13.5 A (650W)

Model HHP650PS48 (Input: 180-277Vac): Output Rated: 48.0 Vdc, 16.2 A (780W)

Additional Information

The need for the additional testing and evaluation shall be determined in the end product investigation.

Issue Date: 2013-08-19 Page 7 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

The nameplate markings provided as an Enclosure - Marking Plate are considered representative of the entire series.

The power supply series covered by this report employ Double/Reinforced Insulation between Primary and Secondary circuits.

Technical Considerations

- The product was submitted and evaluated for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification of: 50°C at full rated load and 70°C at half rated load.
- The means of connection to the mains supply is: for building-in, to be determined in the end product.
- The product is intended for use on the following power systems: TN
- The equipment disconnect device is considered to be: for building-in, to be determined in the end product.
- The product was investigated to the following additional standards: EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 (which includes all European national differences, including those specified in this test report).
- The following are available from the Applicant upon request: Specific data sheets for LED indicators that are class I and operate at wavelength in the 400-710 nm range.,
- LEDs provided in the product are considered low power devices: Yes
- Per manufacturer specifications, the Electric Strength Test from input to ground conducted at 2000Vac. --

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The following Production-Line tests are conducted for this product: Electric Strength, Earthing Continuity
- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-Earthed Dead Metal: 277 Vrms, 390 Vpk, Primary-SELV: 360 Vrms, 534 Vpk,
- The following secondary output circuits are SELV: All outputs
- The following secondary output circuits are at hazardous energy levels: Power output
- The following secondary output circuits are at non-hazardous energy levels: 5V Standby output
- The power supply terminals and/or connectors are: Not investigated for field wiring
- The maximum investigated branch circuit rating is: 20 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: Required
- An investigation of the protective bonding terminals has: Not been conducted
- The following input terminals/connectors must be connected to the end-product supply neutral: AC-N
 (J1)
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): L1-L3, L50, T201, T301-T303, and L301 (Class F),
- The following end-product enclosures are required: Electrical, Fire, Mechanical
- The following LEDs operate within the exempt group per IEC 62471: Indicating LED.

Issue Date: 2013-08-19 Page 8 of 9 Report Reference # E139109-A127-CB-1

Amendment 1 2014-02-18

• Fans: The fan provided in this sub-assembly is not intended for operator access.

- GDT, meeting basic insulation, provided in series with Line to Ground VDR in order to meet the requirements of sub-clause 1.5.9.4. --
- Temperature, Leakage, Earthing, and Dielectric to be considered as part of the end product investigation. --
- Required values for clearance are adjusted for 5000m(1.48 correction factor as per IEC 60664-1, Table A2) --
- Unit was evaluated as a component for building-in, the need for markings and marking durability testing shall be determined as part of the end product. --
- Output terminals V+ and V- are provided with multiple pole terminals (3) rated 20 A per pole totaling up to no more than a maximum of 50 A device output., --

Abbreviations used in the report:				
- normal condition	N.C.	- single fault condition	.S.F.C	
- operational insulation	OP	- basic insulation	.BI	
- basic insulation between parts of opposite polarity:	ВОР	- supplementary insulation	.SI	
- double insulation	DI	- reinforced insulation	.RI	
Indicate used abbreviations (if any)				