

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**

Product  
Produit

DC-DC Converter

Name and address of the applicant  
Nom et adresse du demandeur

XP POWER INC  
SUITE 150  
1241 E DYER RD  
SANTA ANA CA 92705, USA

Name and address of the manufacturer  
Nom et adresse du fabricant

XP POWER INC  
SUITE 150  
1241 E DYER RD  
SANTA ANA CA 92705, USA

Name and address of the factory  
Nom et adresse de l'usine

CINCON ELECTRONICS CO LTD  
8-1 FU KUNG RD FU HSING PARK FU HSING HSIANG  
CHANGHUA HSIEN 506  
TAIWAN

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Additional Information on page 2  
See Page 2

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Trademark (if any)  
Marque de fabrique (si elle existe)



SMT

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais  
constructeur

JHM10XXDYY, JHM10XXSYY

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,,  
peuvent être indiqués sur la 2<sup>ème</sup> page

National Differences specified in the CB Test Report.  
 Additional Information on page 2

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60601-1(ed.3)

As shown in the Test Report Ref. No. which forms  
part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

E321744-A9-CB-1 issued on 2012-01-26

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2012-01-26

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

**US-18397-UL**

**Model Details:**

JHM10XXDYY, JHM10XXSY (where 'XX' = 05, 12, or 24; 'YY' = 05, 12, 15; and maybe provided optional suffix - SG01)

**Factories:**

DONGGUAN DONGCHENG ZHUSHAN CINCON ELECTRONICS FACTORY  
1 JING XIANG RD DONGCHENG FOREIGN TRADE INDUSTRIAL PARK  
ZHUSHAN DONGCHENG DISTRICT  
DONGGUAN 523128 GUANGDONG  
CHINA

**Ratings:**

**Input:**

For Models JHM1005SY and JHM1005DY Series: 4.5-9Vdc, 2700mA;

For Models JHM1012SY and JHM1012DY Series: 9-18Vdc, 1300mA;

For Models JHM1024SY and JHM1024DY Series: 18-36Vdc, 650mA

Output: See Model Differences for details.

**Additional information (if necessary)**

**Information complémentaire (si nécessaire)**



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA



UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK



UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN



UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2012-01-26

Signature:

Jolanta M. Wroblewska



Test Report issued under  
the responsibility of:



**TEST REPORT**  
**IEC 60601-1**  
**Medical Electrical Equipment**  
**Part 1: General requirements for basic safety and essential performance**

**Report Reference No** .....: E321744-A9-CB-1

**Date of issue** .....: 2012-01-26

**Total number of pages** .....: 191

**CB Testing Laboratory** .....: UL Camas

**Address** .....: 2600 N.W. Lake Road, Camas, WA, 98607, USA

**Applicant's name** .....: XP POWER INC  
SUITE 150

**Address** .....: 1241 E DYER RD  
SANTA ANA CA 92705  
UNITED STATES

**Test specification:**

**Standard** .....: IEC 60601-1: 2005 + CORR. 1 (2006) + CORR. 2 (2007)

**Test procedure** .....: CB Scheme

**Non-standard test method** .....: N/A

**Test Report Form No.** .....: IEC60601\_1G

**Test Report Form originator** .....: UL LLC


**Master TRF** .....: Dated 2010-11

**Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

<b>Test item description</b> .....	DC-DC Converter
Trade Mark .....	
Manufacturer .....	XP POWER INC SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES
Model/Type reference .....	JHM10XXSYY and JHM10XXDYY series (where 'XX' =05, 12, or 24; 'YY' = 05, 12, 15; and maybe provided optional suffix -SG01)
Ratings .....	Input: For Models JHM1005SYY and JHM1005DYY Series: 4.5-9Vdc, 2700mA;  For Models JHM1012SYY and JHM1012DYY Series: 9-18Vdc, 1300mA;  For Models JHM1024SYY and JHM1024DYY Series: 18-36Vdc, 650mA  Output: See Model Differences for details.

<b>Testing procedure and testing location:</b>	
<input type="checkbox"/> <b>CB Testing Laboratory</b>	Testing location / address..... :
<input type="checkbox"/> <b>Associated CB Test Laboratory</b>	Testing location / address..... :
	Tested by (name + signature) ..... : _____
	Approved by (name + signature) ... : _____
<input type="checkbox"/> <b>Testing Procedure: TMP</b>	Tested by (name + signature) ..... : _____
	Approved by (+ signature) ..... : _____
	Testing location / address..... :
<input type="checkbox"/> <b>Testing Procedure: WMT</b>	Tested by (name + signature) ..... : _____
	Witnessed by (+ signature)..... : _____
	Approved by (+ signature) ..... : _____
	Testing location / address..... :
<input checked="" type="checkbox"/> <b>Testing Procedure: SMT</b>	Tested by (name + signature) ..... : Chin Chee Siang
	Approved by (+ signature) ..... : Tac Pham
	Supervised by (+ signature) ..... : Michael J. Howell
	Testing location / address..... : XP POWER LTD, 401 COMMONWEALTH DR HAW PAR TECHNOCENTRE LOBBY B, #02-02, SINGAPORE 149598 Singapore, XP POWER LLC, SUITE 150, 1241 E DYER RD, SANTA ANA, CA 92705 UNITED STATES
<input type="checkbox"/> <b>Testing Procedure: RMT</b>	Tested by (name + signature) ..... : _____
	Approved by (+ signature) ..... : _____
	Supervised by (+ signature) ..... : _____
	Testing location / address..... :

**List of Attachments**

National Differences (9 pages)

Enclosures (89 pages)

**Summary Of Testing**

Unless otherwise indicated, all tests were conducted at XP POWER LTD, 401 COMMONWEALTH DR HAW PAR TECHNOCENTRE LOBBY B, #02-02, SINGAPORE 149598 Singapore, XP POWER LLC, SUITE 150,

1241 E DYER RD, SANTA ANA, CA 92705 UNITED STATES.

Tests performed (name of test and test clause)	Testing location / Comments
Power Input Test (4.11)	
Humidity Preconditioning Treatment (5.7)	XP Power LLC, 1241 E. Dyer Rd., Suite 150, Santa Ana, CA 92705
Working Voltage Measurement (8.5.4)	
Dielectric Voltage Withstand (8.8.3)	Also tested at XP Power LLC, 1241 E. Dyer Rd., Suite 150, Santa Ana, CA 92705
Ball Pressure (8.8.4.1)	XP Power LLC, 1241 E. Dyer Rd., Suite 150, Santa Ana, CA 92705
Temperature Test (11)	
Abnormal Operation and Single Fault Conditions (13)	
Power Availability (13.1.2)	
Transformer Overload and Short-Circuit Tests (15.5.1)	
Transformer Dielectric Voltage Withstand (15.5.2)	
<b>Summary of Compliance with National Differences:</b>	
Countries outside the CB Scheme membership may also accept this report.	
List of countries addressed: AT, BE, CA, CH, CZ, DE, DK, FI, FR, GB, HU, IT, NL, NO, PL, SE, SI, SK, TR, UA, US	
The product fulfills the requirements of: CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) (includes National Differences for Canada), ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) (includes Deviations for United States)	

**Copy of Marking Plate** - Refer to Enclosure titled Marking Plate for copy.

<b>Test item particulars (see also Clause 6):</b>		
Classification of installation and use .....	Building In	
Device type (component/sub-assembly/ equipment/ system) .....	Component	
Intended use (Including type of patient, application location) .....	Component DC-DC converter for use in medical power supplies	
Mode of operation .....	Continuous	
Supply connection .....	Isolated Secondary	
Accessories and detachable parts included .....	None	
Other options include .....	None	
<b>Testing:</b>		
Date of receipt of test item(s) .....	2011-04-18, 2012-01-10	
Dates tests performed .....	2011-06-20 to 2011-06-30, 2012-01-17, 2012-01-10 to 2012-01-12	
<b>Possible test case verdicts:</b>		
- test case does not apply to the test object .....	N / A	
- test object does meet the requirement .....	P(Pass)	
- test object was not evaluated for the requirement :	N / E	
- test object does not meet the requirement .....	F(Fail)	
<b>Abbreviations used in the report:</b>		
- normal condition .....	N.C. - single fault condition .....	S.F.C.
- means of Operator protection .....	MOOP - means of Patient protection .....	MOPP
<b>General remarks:</b>		
<p>"(see Attachment #)" refers to additional information appended to the report.                  "(see appended table)" refers to a table appended to the report.</p> <p>The test results presented in this report relate only to the object tested.                  This report shall not be reproduced, except in full, without the written approval of the testing laboratory.                  List of test equipment must be kept on file and available for review.                  Additional test data and/or information provided in the attachments to this report.</p> <p>Throughout this report a point is used as the decimal separator.</p>		
<b>Manufacturer's Declaration per Sub Clause 6.25 of IEC60601-1:</b>		
The application for obtaining a CB Test Certificate includes more than one factory and a declaration form the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided .....	Yes	
When differences exist, they shall be identified in the General Product Information section.		
<b>Name and address of Factory(ies):</b>	CINCON ELECTRONICS CO LTD 8-1 FU KUNG RD FU HSING PARK FU HSING HSIANG	

CHANGHUA HSIEN  
506 TAIWAN

DONGGUAN DONGCHENG ZHUSHAN CINCON  
ELECTRONICS FACTORY  
1 JING XIANG RD DONGCHENG FOREIGN TRADE  
INDUSTRIAL PARK  
ZHUSHAN DONGCHENG DISTRICT  
DONGGUAN 523128 GUANGDONG  
CHINA

## GENERAL PRODUCT INFORMATION:

### Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

### Product Description

The unit is a DC/DC Converter to be used as part of Medical Electrical Equipment, and is intended to provide Two MOPP between DC input circuits to DC output circuit.

The unit is provided with top and bottom plastic enclosure. All components inside the unit are mounted on PWB.

### Model Differences

Model JHMXXDYY Series is identical to Model JHMXXSYY Series with except it is provided with two output instead of one.

All models within a series are identical except for transformer windings, inductance and MOSFETs, and output ratings.

See below for Model Output Ratings @ 50°C.

JHM10XXS05: 5 Vdc, 2000mA  
JHM10XXS12: 12Vdc, 833mA  
JHM10XXS25: 15Vdc, 666mA  
JHM10XXD05: 5Vdc, 1000mA; 5Vdc, 1000mA  
JHM10XXD12: 12Vdc, 420mA; 12Vdc, 420mA  
JHM10XXD15: 15Vdc, 333mA; 15Vdc, 333mA

Where XX can be 05, 12, 15 and denotes nominal input voltage ranges as follows:

05 = 4.5-9Vdc  
12 = 9-18Vdc  
24 = 18-36 Vdc

Additional suffix "-SG01" maybe provided but not related to safety.

### Additional Information

Marking label submitted is representative of all models in this Report.



CB Test certificates for components are included in Licenses Enclosure. In accordance with the current rules of CB Scheme, CB Test certificate is effective for 3 years. Recognizing NCB may challenge the CBTC when certificates are more than 3 years old.

When submitting this Test Report to other Certification Body, the manufacturer is responsible for providing any additional information that the Body may need in order to issue its Mark, including testing for compliance with the applicable collateral standards.

### Technical Considerations

- The product was investigated to the following additional standards: CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) (includes National Differences for Canada), ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) (includes Deviations for United States)
- The product was not investigated to the following standards or clauses: Electromagnetic Compatibility (IEC 60601-1-2), Clause 14, Programmable Electronic Systems, Biocompatibility (ISO 10993-1)
- The degree of protection against harmful ingress of water is: Ordinary
- The following accessories were investigated for use with the product: None
- The mode of operation is: Continuous
- The product is suitable for use in the presence of a flammable anesthetics mixture with air or oxygen or with nitrous oxide: No
- Scope of this evaluation defers the following clauses to the be determined as part of the end product: Clause 7.5 (Safety Signs), Clause 7.9 (Accompanying Documents), Clause 9 (ME Hazard), Clause 10 (Radiation), Clause 14 (PEMS), Clause 16 (ME Systems). --
- Scope of this evaluation excludes the following: Patient applied parts clauses: 4.6, 7.2.10, 8.3, 8.5.2, 8.5.5, 8.7.4.7-8.7.4.9, 8.9.1.15; Battery related clauses: 7.3.3, 15.4.3; Hand Control related clauses: 8.10.4; Oxygen related clauses: 11.2.2; Fluids related clauses: 11.6.2 – 11.6.4; Sterilization clause: 11.6.7; Biocompatibility Clause: 11.7 (ISO 10993); Motor related clauses: 13.2.13.3, 13.4; Heating Elements related clause: 13.2; Flammable Anaesthetic Mixtures Protection: Annex G. --

### Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- This power supply has been judged on the basis of the required creepage and clearances in the Third Edition of the Standard for Medical Electrical Equipment, IEC 60601-1, Sub-clause 8.9, which covers the end-use product for which the component was designed. --

- The unit is a DC/DC converter and not evaluated for the separation to SUPPLY MAINS; suitable MAINS separation shall be provided during final installation. --
- Temperature, Leakage Current, Protective Earthing Dielectric Voltage Withstand and Interruption of the Power Supply tests should be considered as part of the end product evaluation. --
- The product was submitted and tested for use at the manufacturer's recommended ambient temperature (T<sub>mra</sub>) of 70°C at Full Load. --
- The output circuit has not been evaluated for connecting to Applied Parts. For end products intended to connect to Applied Parts, suitable evaluation should be considered. --
- Considerations to the applied parts requirement, to be conducted as end-product --
- Consideration should be given to measuring the temperature on power electronic components and transformer windings when the power supply is installed in the end-use equipment. The end-use product shall ensure that the power supply is used within its ratings. --
- The end-product evaluation shall ensure that the requirements related to Accompanying Documents, Clause 7.9 are met. --
- End product Risk Management Process to include consideration of requirements specific to the Power Supply. --
- End product Risk Management Process to consider the need for simultaneous fault condition testing. --
- End product to determine the acceptability of risk in conjunction to insulation to resistance to heat, moisture, and dielectric strength. --
- End product to determine the acceptability of risk in conjunction to the Leakage of Liquids as part of the power supply. --
- End product to determine the acceptability of risk in conjunction to the selection of components as it pertains to the intended use, essential performance, transport, storage conditions as part of the power supply. --
- The products were tested on a 20 A branch circuit. If used on a branch circuit greater than this, additional testing may be necessary. --