

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**

Product  
Produit

Power supply for building-in, switch mode type

Name and address of the applicant  
Nom et adresse du demandeur

XP POWER LLC  
SUITE 150  
1241 E DYER RD  
SANTA ANA CA 92705, USA

Name and address of the manufacturer  
Nom et adresse du fabricant

XP POWER LLC  
SUITE 150  
1241 E DYER RD  
SANTA ANA CA 92705, USA

Name and address of the factory  
Nom et adresse de l'usine

XP POWER INC  
990 BENEZIA AVE  
SUNNYVALE CA 94085  
USA

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Additional Information on page 2

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Input: 100-240 Vac, 50/60 Hz, 2.2 A.  
Output: 56 Vdc, 1.78 A, 100 W Max with forced air cooling

Trademark (if any)  
Marque de fabrique (si elle existe)



Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais  
constructeur

POE100US56

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,,  
peuvent être indiqués sur la 2<sup>ème</sup> page

National Differences specified in the CB Test Report.

Additional Information on page 2

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1

As shown in the Test Report Ref. No. which forms  
part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

E139109-A22-CB-2 issued on 2012-12-20

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA



UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK



UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN



UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2012-12-20

Signature:

Jolanta M. Wroblewska

## Factories:

XP POWER (KUNSHAN) LIMITED  
230 BIN JIANG NAN ROAD  
ZHANG PU TOWN  
KUNSHAN, JIANGSU 215300  
CHINA

XP POWER (S) PTE LTD  
LIPO BLDG, #05-01  
621 ALJUNIED RD  
SINGAPORE 389834  
SINGAPORE

**Additional information (if necessary)****Information complémentaire (si nécessaire)**

UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2012-12-20

Signature:

Jolanta M. Wroblewska



Test Report issued under  
the responsibility of:



**TEST REPORT**  
**IEC 60950-1**  
**Information technology equipment - Safety -**  
**Part 1: General requirements**

**Report Reference No** .....: E139109-A22-CB-2

Date of issue .....: 2012-12-20

Total number of pages .....: 65

**CB Testing Laboratory** .....: UL San Jose

Address .....: 455 E. Trimble Rd., San Jose, CA, 95131-1230, USA

**Applicant's name** .....: XP POWER LLC

SUITE 150

Address .....: 1241 E DYER RD

SANTA ANA CA 92705

UNITED STATES

**Test specification:**

Standard .....: IEC 60950-1:2005 (2nd Edition); Am 1:2009

Test procedure .....: CB Scheme

Non-standard test method .....: N/A

**Test Report Form No.** .....: IEC60950\_1B

Test Report Form originator .....: SGS Fimko Ltd


Master TRF .....: 2010-04



**Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**


<b>Test item description</b> .....	Power supply for building-in, switch mode type
Trade Mark .....	
Manufacturer .....	XP POWER LLC SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES
Model/Type reference .....	POE100US56
Ratings .....	Input: 100-240 Vac, 50/60 Hz, 2.2 A. Output: 56 Vdc, 1.78 A, 100 W Max with forced air cooling

<b>Testing procedure and testing location:</b>	
<input type="checkbox"/> <b>CB Testing Laboratory</b>	Testing location / address..... :
<input checked="" type="checkbox"/> <b>Associated CB Test Laboratory</b>	Testing location / address..... : UL Brea 2929 Imperial Hwy, Ste 100, Brea, CA, 92821, USA
	Tested by (name + signature) ..... : Jason Ferguson 
	Approved by (name + signature) ... : Randy Johnson 
<input type="checkbox"/> <b>Testing Procedure: TMP</b>	Tested by (name + signature) ..... : _____
	Approved by (+ signature) ..... : _____
	Testing location / address..... : _____
<input type="checkbox"/> <b>Testing Procedure: WMT</b>	Tested by (name + signature) ..... : _____
	Witnessed by (+ signature)..... : _____
	Approved by (+ signature)..... : _____
	Testing location / address..... : _____
<input type="checkbox"/> <b>Testing Procedure: SMT</b>	Tested by (name + signature) ..... : _____
	Approved by (+ signature) ..... : _____
	Supervised by (+ signature) ..... : _____
	Testing location / address..... : _____
<input type="checkbox"/> <b>Testing Procedure: RMT</b>	Tested by (name + signature) ..... : _____
	Approved by (+ signature) ..... : _____
	Supervised by (+ signature) ..... : _____
	Testing location / address..... : _____

<b>List of Attachments</b>
National Differences (37 pages)
Enclosures (34 pages)
<b>Summary of Testing:</b>
All Applicable tests according to the referenced standard(s) have been carried out
<b>Summary of Compliance with National Differences:</b>
Countries outside the CB Scheme membership may also accept this report.
List of countries addressed: AT, BE, BG, BY, CA, CH, CZ, DE, DK, ES, EU, FI, FR, GB, GR, HU, IE, IL, IT, JP, KR, NL, PL, PT, RO, SE, SI, SK, UA, US

**Copy of Marking Plate**

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.



<b>Test item particulars :</b>	
Equipment mobility .....	for building-in
Connection to the mains .....	for building-in
Operating condition .....	continuous
Access location .....	operator accessible
Over voltage category (OVC) .....	OVC II
Mains supply tolerance (%) or absolute mains supply values .....	+10%, -10%
Tested for IT power systems .....	No
IT testing, phase-phase voltage (V) .....	N/A
Class of equipment .....	Class I or Class II (Determined by end product)
Considered current rating of protective device as part of the building installation (A) .....	20 A
Pollution degree (PD) .....	PD 2
IP protection class .....	IPX0
Altitude of operation (m) .....	Up to 3048 m
Altitude of test laboratory (m) .....	less than 2000 meters
Mass of equipment (kg) .....	0.17 kg
<b>Possible test case verdicts:</b>	
- test case does not apply to the test object .....	N / A
- test object does meet the requirement .....	P(Pass)
- test object does not meet the requirement .....	F(Fail)
<b>Testing:</b>	
Date(s) of receipt of test item .....	2008-09-26, 2008-10-01
Date(s) of Performance of tests .....	2008-10-13 to 2008-10-17
<b>General remarks:</b>	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the testing laboratory.	
"(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.	
Throughout this report a point is used as the decimal separator.	
<b>Manufacturer's Declaration per Sub Clause 6.25 of IEC60950-1:</b>	
The application for obtaining a CB Test Certificate includes more than one factory and a declaration form the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided .....	
When differences exist, they shall be identified in the General Product Information section.	
<b>Name and address of Factory(ies):</b>	XP POWER INC 990 BENECIA AVE SUNNYVALE CA 94085 USA

XP POWER (KUNSHAN) LIMITED  
230 BIN JIANG NAN ROAD  
ZHANG PU TOWN  
KUNSHAN,  
JIANGSU 215300 CHINA

XP POWER (S) PTE LTD  
LIPO BLDG, #05-01  
621 ALJUNIED RD  
SINGAPORE 389834 SINGAPORE

## GENERAL PRODUCT INFORMATION:

### Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

### Product Description

The model covered in this report is a component power supply intended for use in Information Technology Equipment. It is an open frame power supply intended for building-in Class I or Class II end-products. Double insulated symbol is optionally provided. Earthing symbol may only be provided for Class I power supplies. The need for the additional testing and evaluation shall be determined in the end product investigation.

The power supply covered by this report employ Double/Reinforced Insulation between Primary and Secondary circuits.

When installed in a Class I end product, the power supply shall be mounted in a manner that provides, at a minimum, 2 mm Clearance between the primary side of power supply and protectively earthed accessible conductive parts. In addition, when installed in a Class I end product, the protective bonding terminal of the power supply shall be reliably connected to the main protective earthing terminal of the end product.

When installed in a Class II end product, the power supply shall be mounted, on insulating posts, in a manner that provides, at a minimum, 4 mm Clearance between the power supply and any accessible conductive parts.

### Model Differences

N/A

### Additional Information

Only limited tests were performed on model POE100US56 because of similarity in construction to previous model ECM80US56.

This report is a reissue of CBTR Ref. No.E139109-A22-CB-1, CB Test Certificate Ref. Nos.US/13315/UL. Based on previously conducted testing and the review of product construction it was determined that the product continues to comply with the standard.

Some of the attached Critical Component Licenses/Certs may be more than 3 years old. Manufacturer to



provide updated licenses upon request from an accepting NCB.

The Critical Components Table includes components in the product as submitted and also includes, in certain cases, alternate generic descriptions (designated as "interchangeable") for equivalent component substitutions. Recognizing NCBs may require additional information and/or evaluation to qualify alternate components.

User's Manuals, instructions and markings will be provided in the national language of the country of sale. The manufacturer is aware of the requirements for language requirements for markings/instructions, cords/cables, plugs and EMC. Detailed information may be obtained directly from the client. See Enclosure-Miscellaneous for a Letter of Assurance.

### Technical Considerations

- The product was submitted and evaluated for use at the maximum ambient temperature (T<sub>ma</sub>) permitted by the manufacturer's specification of: 50 °C at 80W convection cooled; maximum ambient temperature of 50 °C at Maximum load (100W) with 10CFM forced air cooled; and for a maximum ambient temperature of 70°C at Half load (50W) with 10CFM forced air cooled.,
- The means of connection to the mains supply is: for building-in
- The product is intended for use on the following power systems: TN
- The following accessible locations (with circuit/schematic designation) are within a limited current circuit: Load side of C17 (Pri to Sec bridging capacitor)
- Power supplies covered by this report were evaluated for both Class I and Class II (double insulated). Double insulated symbol is optionally provided. See Conditions of Acceptability for insulation required for Class II. Earthing symbol may only be provided for Class I power supplies. --

### Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The following Production-Line tests are conducted for this product: Electric Strength
- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-SELV: 201 Vrms, 462 Vpk
- The following secondary output circuits are SELV: All outputs
- The following secondary output circuits are at non-hazardous energy levels: All outputs
- The power supply terminals and/or connectors are: Suitable for factory wiring only
- The maximum investigated branch circuit rating is: 20 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: required when the power supply is used in a Class I end product. The power supply will be considered Class II when protection against electric shock does not rely on Basic Insulation only, unit provides additional safety precautions such as Double/Reinforced Insulation and provide minimum of 5 mm creepage and 4 mm clearance distance (mounted above chassis/accessible metal parts on Insulating posts etc). Class II units have no reliance upon protective earthing.
- An investigation of the protective bonding terminals has: Not been conducted
- The following input terminals/connectors must be connected to the end-product supply neutral: ACN J1-3
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJ2 insulation

system with the indicated rating greater than Class A (105°C): L1, L2 and T1 (Class F)

- The following end-product enclosures are required: Electrical, Fire
- The maximum continuous power supply output (Watts) relied on forced air cooling from: 50 W and 100 W with external 10 cfm fan applied to the front of the power supply, 5cm from the AC input connector. Maximum 80 W convection cooling.
- The equipment is suitable for direct connection to: AC mains supply
- Printed Wiring Board rated 130°C. --
- The equipment is provided with a fuse in the hot line of the primary circuit. --
- Heatsinks are floating and considered live. They should not be accessible in the end-product. --
- Consideration to repeating the Touch Current test should be given in the end-product evaluation. --

Abbreviations used in the report:

- normal condition .....	N.C.	- single fault condition .....	S.F.C
- operational insulation .....	OP	- basic insulation .....	BI
- basic insulation between parts of opposite polarity:	BOP	- supplementary insulation .....	SI
- double insulation .....	DI	- reinforced insulation .....	RI

Indicate used abbreviations (if any)