



TEST REPORT IEC 62368-1

Audio/video, information and communication technology equipment Part 1: Safety requirements

Report Number: E139109-A6063-CB-1

Date of issue...... 2018-11-29

Total number of pages 81

Applicant's name...... XP POWER L L C

Address 15641 RED HILL AVE, SUITE 100

TUSTIN CA 92780 UNITED STATES

Name of Test Laboratory UL Camas

preparing the Report 2600 N.W. Lake Road, Camas, WA, 98607, USA

Test specification:

Standard IEC 62368-1:2014 (Second Edition)

Test procedure CB Scheme

Non-standard test method.....: N/A

Test Report Form No...... IEC62368 1B

Copyright © 2014 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Issue Date: 2018-11-29 Page 2 of 81 Report Reference # E139109-A6063-CB-1

Manufacturer
15641 RED HILL AVE, SUITE 100
1100111107 32700
UNITED STATES
Model/Type reference
Children Type Toleroniae
Where XX is between 12-48.
Ratings : INPUT ~ 100 - 240VAC 50/60Hz 4.6A
or
INPUT ~ 100 - 120VAC 50/60/400Hz 4.6A
Output: See Model Differences.
Calpul Goo Model 2 molecules
Testing procedure and testing location:
☐ CB Testing Laboratory:
Testing location/ address:
Associated CB Testing Laboratory:
Testing location/ address:
Totally (comparison as)
Tested by (name + signature):
Approved by (name + signature):
Testing procedure: TMP/CTF Stage 1
Testing location/ address:
Tested by (name + signature):
Approved by (name + signature):
Approved by (marrier signature)
☐ Testing procedure: WMT/CTF Stage 2
Testing location/ address:
resumg location/ address
Tested by (name + signature):
Witnessed by (name + signature):
Approved by (name + signature):
☐ ☐ Testing procedure: SMT/CTF Stage 3

Issue Date: 2018-11-29 Page 3 of 81 Report Reference # E139109-A6063-CB-1

Testing location/ address:	XP POWER LLC, 15641 RED HILL AVE, SUITE 100, TUSTIN , CA 92780, USA	
Tested by (name + signature):	Rodney Reyes / Tester	Rodney Reyes
Approved by (name + signature):	Gregory Ray / Reviewer	Sugary Ray
Supervised by (name + signature):	Adam Tangocci / Supervisor	Adam Tangocci

Issue Date: 2018-11-29 Page 4 of 81 Report Reference # E139109-A6063-CB-1 List of Attachments (including a total number of pages in each attachment): National Differences (23 pages) Enclosures (38 pages) Summary of testing: Unless otherwise indicated, all tests were conducted at XP POWER LLC, 15641 RED HILL AVE, SUITE 100, TUSTIN, CA 92780, USA. Tests performed (name of test and test clause): **Testing location:** XP POWER LLC, 15641 RED HILL AVE, SUITE 100, TUSTIN, CA 92780, USA ELECTRIC STRENGTH TEST (5.4.9) PROSPECTIVE TOUCH VOLTAGE AND TOUCH **CURRENT MEASUREMENT (5.7) Summary of compliance with National Differences:** List of countries addressed: AU,NZ, EU Group Differences, US,CA ☐ The product fulfils the requirements of: EN 62368-1:2014 + A11:2017

2018-11-29 Page 5 of 81 Copy of Marking Plate - Refer to Enclosure titled Marking Plate for copy.

Report Reference #

E139109-A6063-CB-1

Issue Date:

Issue Date: 2018-11-29 Page 6 of 81 Report Reference # E139109-A6063-CB-1

TEST ITEM PARTICULARS:			
Classification of use by	Ordinary person		
Supply Connection	AC Mains		
Supply % Tolerance	+10%/-10%		
Supply Connection – Type	For building-in		
Considered current rating of protective device as part	20 A;		
of building or equipment installation	building;		
Equipment mobility	for building-in		
Over voltage category (OVC)	OVC II		
Class of equipment	Not Classified		
Access location	N/A		
Pollution degree (PD)	PD 2		
Manufacturer's specified maximum operating ambient	See Model Differences section. °C		
IP protection class	IPX0		
Power Systems	TN		
Altitude during operation (m)	3048 m		
Altitude of test laboratory (m)	2000 m or less		
Mass of equipment (kg)	1.8		
POSSIBLE TEST CASE VERDICTS:			
- test case does not apply to the test object:	N/A		
- test object does meet the requirement:	P (Pass)		
- test object does not meet the requirement:	F (Fail)		
TESTING:			
Date of receipt of test item:	2011-06-18, 2014-11-03, 2018-03-05, 2018-09-25		
Date (s) of performance of tests:	2011-07-18 TO 2011-07-27, 2014-11-10, 2018-06-29, 2018-09-25		
GENERAL REMARKS:			
"(See Enclosure #)" refers to additional information "(See appended table)" refers to a table appended to Throughout this report a □ comma / ☒ point is us	o the report.		
Manufacturer's Declaration per sub-clause 4.2.5 of IECEE 02:			
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	✓ Yes☐ Not applicable		

Issue Date: 2018-11-29 Page 7 of 81 Report Reference # E139109-A6063-CB-1

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies):

XP POWER (KUNSHAN) LTD 230 BIN JIANG NAN RD ZHANGPU TOWN KUNSHAN JIANGSU 215300 CHINA

XP POWER (VIETNAM) CO LTD LOT D - 4Q - CN MY PHUOC 3 INDUSTRIAL PARK BEN CAT DISTRICT BINH DUONG BINH DUONG VIETNAM

XP POWER PLC
16 HORESHOE PARK
PANGBOURNE
RG8 7JW UNITED KINGDOM

XP POWER LIMITED LIPO BLDG, #05-01 621 ALJUNIED RD SINGAPORE 389834 SINGAPORE

XP POWER LLC 990 BENECIA AVE SUNNYVALE CA 94085 UNITED STATES

GENERAL PRODUCT INFORMATION:

Product Description

The product is a component AC-DC power supply for building-in, open frame type provided with a metal chassis.

Model Differences

All models with the series are identical, with exception to the output voltage and current ratings, number of turns of primary/secondary windings in the Transformers (T302 (Power)), and minor differences in the secondary circuit components and PWB layout. The 400 Hz rating is optional.

See below for Model Ratings Table (up to 50°C) for Model SHP350PSXX, where XX indicates the output voltage:

When input is between 100-240 Vac:

Model SHP350PS12: 10.1 Vdc to 13.5 Vdc, 26.5A (318W Max.)

Model SHP350PS15: 13.6 Vdc to 17 Vdc, 22 A (330W Max.)

Model SHP350PS18: 17.1 Vdc to 21 Vdc, 18.3 A (330W Max.)

Model SHP350PS24: 21.1 Vdc to 26 Vdc, 14.5 A (350W Max.)

Model SHP350PS28: 26.1 Vdc to 31 Vdc, 12.5 A (350W Max.)

Model SHP350PS33: 31.1 Vdc to 33 Vdc, 10.6 A (350W Max.)

Model SHP350PS36: 33.1 Vdc to 42 Vdc, 9.7 A (350W Max.)

Model SHP350PS48: 42 Vdc to 54 Vdc, 7.3 A (350W Max.)

Issue Date: 2018-11-29 Page 8 of 81 Report Reference # E139109-A6063-CB-1

When input is between 180-240 Vac:

Model SHP350PS24: 21.1 Vdc to 26 Vdc, 17.5 A (420W Max.) Model SHP350PS28: 26.1 Vdc to 31 Vdc. 15 A (420W Max.)

Model SHP350PS33: 31.1 Vdc to 33 Vdc, 12.7 A (420W Max.)

Model SHP350PS36: 33.1 Vdc to 42 Vdc, 11.7 A (420W Max.)

Model SHP350PS48: 42 Vdc to 54 Vdc, 8.75 A (420W Max.)

All models also provided with 5V, 0.2A stand-by output.

50°C at full rated load and 70°C at half rated load.

Additional application considerations – (Considerations used to test a component or sub-assembly) - Marking Plate is representative of all models.

This report is based on a previous evaluation to IEC 60950-1:2005 (2nd Ed.), Am1:2009 + Am2:2013 under CBTR Ref. No. E139109-A91-CB-2 including Amendments, CBTC Ref. No. US-25918-UL. Based on the previously conducted performance testing, only the tests conducted as part of this investigation were considered necessary.

The following tests were conducted under CTDP SMT/CTF Stage 3 to IEC 60950-1 E2+A1+A2 at XP POWER LLC, 15641 RED HILL AVE, SUITE 100, TUSTIN, CA 92780, USA:

Input: Single-Phase (1.6.2)

Capacitance Discharge (2.1.1.7)

SELV Reliability Test Including Hazardous Voltage Measurements (2.2.2, 2.2.3, 2.2.4, Part 22 6.1)

Humidity (2.9.1, 2.9.2, 5.2.2)

Determination of Working Voltage; Working Voltage Measurement (2.10.2)

Distance Through Insulation Measurements (2.10.5)

Heating (4.5.1, 1.4.12, 1.4.13)

Ball Pressure (4.5.5, 4.5)

Electric Strength (5.2.2)

Component Failure (5.3.1, 5.3.4, 5.3.7)

Abnormal Operation (5.3.1 - 5.3.9)

Transformer Abnormal Operation (5.3.3, 5.3.7b, Annex C.1)

Power Supply Output Short-Circuit/Overload (5.3.7)

The following additional tests were conducted on a sample of model SHP350PS12 in accordance with IEC 62368-1:2014 (Second Edition) at XP POWER LLC, 15641 RED HILL AVE, SUITE 100, TUSTIN, CA 92780 USA:

Electric Strength Test (5.4.9)

Prospective Touch Voltage and Touch Current Measurement (5.7)

Technical Considerations

- The product was submitted and evaluated for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification of : 50°C at full rated load and 70°C at half rated load.
- The product is intended for use on the following power systems : TN

•

• The equipment disconnect device is considered to be : To be determined in the end-product.

Issue Date: 2018-11-29 Page 9 of 81 Report Reference # E139109-A6063-CB-1

Required Clearances have been adjusted by multiplying the clearance at sea level by a factor of 1.15 for
operating at an altitude of 3048 meters. The correction factor is based on barometric pressure of 70kPa.
If the calculated Clearance exceeded the Creepage, the Creepage was adjusted to the value of
clearance.

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

• The following product-line tests are conducted for this product: Electric Strength

•

- The following output circuits are at ES1 energy levels : All Outputs
- The following output circuits are at PS3 energy levels : All Outputs
- The maximum investigated branch circuit rating is: 20 A

•

The investigated Pollution Degree is: 2

•

- Proper bonding to the end-product main protective earthing termination is: Required (Class I)
- An investigation of the protective bonding terminals has: Not been conducted

•

- The following input terminals/connectors must be connected to the end-product supply neutral: AC N
- The following end-product enclosures are required : Mechanical, Fire, Electrical
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): L1, L2, L50, T201, T301-T303 (Class B)
- The power supply was evaluated to be used at altitudes up to: "3048 m"

•

- When installed in a Class I end product, the power supply shall be mounted in a manner that provides the minimum required Clearance between the primary side of power supply and protectively earthed accessible conductive parts.
- Heatsinks are floating and considered live. They should not be accessible in the end-product.
- A suitable main disconnect device shall be provided in the end product.
- The power supplies covered by this report have a fuse in the neutral of the primary circuit. The need for a marking to warn a service person of the hazards associated with double pole/neutral fusing shall be considered in the end product.
- Consideration to repeating the Touch Current test should be given in the end-product evaluation.
- The power supplies in this report have been subject to Capacitance Discharge testing. Additionally, all
 associated component safeguards have been assessed to the applicable requirement in Annex G.10.
 Additional testing should not be needed if directly connected to mains e.g. using an appliance inlet,
 wiring terminals, etc.