Issue Date: 2012-05-07 Page 1 of 28 Report Reference # E139109-A90-UL

UL TEST REPORT AND PROCEDURE

Standard: UL 60950-1, 2nd Edition, 2011-12-19 (Information Technology Equipment - Safety - Part 1: General Requirements) CSA C22.2 No. 60950-1-07, 2nd Edition, 2011-12 (Information Technology Equipment - Safety - Part 1: General Requirements) **Certification Type:** Component Recognition CCN: QQGQ2, QQGQ8 (Power Supplies for Information Technology Equipment Including Electrical Business Equipment) Product: Switching Power Supplies Model: CCH400PSXX and CCH600PSXX (where XX = can be any number between 12 to 48 designating the output voltage) Rating: Model CCH400PSXX Input: 100-240 Vac, 50/60 Hz, 6.5 A Model CCH600PSXX Input: 100-240 Vac, 50/60 Hz, 8.9 A Output: See Model Differences for ratings. **Applicant Name and Address:** XP POWER INC SUITE 150 1241 E DYER RD SANTA ANA CA 92705 **UNITED STATES**

This is to certify that representative samples of the products covered by this Test Report have been investigated in accordance with the above referenced Standards. The products have been found to comply with the requirements covering the category and the products are judged to be eligible for Follow-Up Service under the indicated Test Procedure. The manufacturer is authorized to use the UL Mark on such products which comply with this Test Report and any other applicable requirements of UL LLC ('UL') in accordance with the Follow-Up Service Agreement. Only those products which properly bear the UL Mark are considered as being covered by UL's Follow-Up Service under the indicated Test Procedure.

The applicant is authorized to reproduce the referenced Test Report provided it is reproduced in its entirety.

UL authorizes the applicant to reproduce the latest pages of the referenced Test Report consisting of the first page of the Specific Technical Criteria through to the end of the Conditions of Acceptability.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Prepared by: Sal Oseguera Reviewed by: Linus Park

Issue Date: 2012-05-07 Page 2 of 28 Report Reference # E139109-A90-UL

Supporting Documentation

The following documents located at the beginning of this Procedure supplement the requirements of this Test Report:

- A. Authorization The Authorization page may include additional Factory Identification Code markings.
- B. Generic Inspection Instructions -
 - Part AC details important information which may be applicable to products covered by this Procedure.
 Products described in this Test Report must comply with any applicable items listed unless otherwise stated in the body of this Test Report.
 - ii. Part AE details any requirements which may be applicable to all products covered by this Procedure. Products described in this Test Report must comply with any applicable items listed unless otherwise stated in the body of each Test Report.
 - iii. Part AF details the requirements for the UL Certification Mark which is not controlled by the technical standard used to investigate these products. Products are permitted to bear only the Certification Mark(s) corresponding to the countries for which it is certified, as indicated in each Test Report.

Product Description

The product is a component AC-DC power supply for building-in, open frame type provided with a metal chassis, incorporating primary and SELV components and a baseplate for conduction cooling.

Model Differences

The power supplies in the series are differentiated by the output voltage and current ratings, number of turns of primary/secondary windings in the Transformer (T1 (Power)) and minor differences in the secondary circuit components.

Model CCH400PSXX Series is identical to Model CCH600PSXX Series with exception to the output ratings for their respective series.

Suffix "XX" denotes the output voltage rating.

See below for Output Ratings:

```
Model CCH400PS12: Output Rated: 12 Vdc, 34.0 A (400 W); Stand-by: 5 V, 0.5A Model CCH400PS24: Output Rated: 24 Vdc, 17.0 A (400 W); Stand-by: 5 V, 0.5A Model CCH400PS28: Output Rated: 28 Vdc, 14.5 A (400 W); Stand-by: 5 V, 0.5A Model CCH400PS48: Output Rated: 48 Vdc, 8.5 A (400 W); Stand-by: 5 V, 0.5A Model CCH600PS12: Output Rated: 12 Vdc, 50.0 A (600 W); Stand-by: 5 V, 0.5A Model CCH600PS24: Output Rated: 24 Vdc, 25 0 A (600 W); Stand-by: 5 V, 0.5A
```

Model CCH600PS24: Output Rated: 24 Vdc, 25.0 A (600 W); Stand-by: 5 V, 0.5A Model CCH600PS28: Output Rated: 28 Vdc, 21.5 A (600 W); Stand-by: 5 V, 0.5A Model CCH600PS48: Output Rated: 48 Vdc, 12.5 A (600 W); Stand-by: 5 V, 0.5A

Technical Considerations

Equipment mobility : for building-in

Connection to the mains: To be determined in the end-use product.

Operating condition : continuous

Issue Date: 2012-05-07 Page 3 of 28 Report Reference # E139109-A90-UL

- Access location: To be determined in the end-use product.
- Over voltage category (OVC) : OVC II
- Mains supply tolerance (%) or absolute mains supply values: +10%, -10%
- Tested for IT power systems : No
- IT testing, phase-phase voltage (V): N/A
- Class of equipment : Class I (earthed)
- Considered current rating of protective device as part of the building installation (A): Model CCH400PSXX: 6.5A, Model CCH600PSXX: 8.9A
- Pollution degree (PD): PD 2
- IP protection class : IP X0
- Altitude of operation (m): 3048
- Altitude of test laboratory (m): 40
- Mass of equipment (kg): 1.5
- The product is intended for use on the following power systems: TN
- The equipment disconnect device is considered to be: determined in the end-product.,
- The product was investigated to the following additional standards: EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 (which includes all European national differences, including those specified in this test report).

Engineering Conditions of Acceptability

For use only in or with complete equipment where the acceptability of the combination is determined by UL LLC. When installed in an end-product, consideration must be given to the following:

- Consideration to repeating Heating and Touch Current Tests should be given in the end-product evaluation.
- Means of disconnection to be provided as part of the end-product.

Issue Date: 2012-05-07 Page 4 of 28 Report Reference # E139109-A90-UL

 Components within the power supply are heat sinked to the base plate of the power supply. The base plate temperature should not exceed 85°C as part of the end product evaluation.

- The maximum continuous power supply output (Watts) relied on the base plate temperature not exceeding 85°C. End product shall determine appropriate heat sink size, maximum recommended ambient temperature, and output load to prevent the base plate temperature from exceeding 85°C.
- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-Earthed Dead Metal: 243 Vrms, 366 Vpk, Primary-SELV: 353 Vrms, 631 Vpk
- The following secondary output circuits are SELV: All outputs
- The following secondary output circuits are at hazardous energy levels: All outputs
- The power supply terminals and/or connectors are: Not investigated for field wiring
- The maximum investigated branch circuit rating is: 20 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: Required
- An investigation of the protective bonding terminals has: Not been conducted
- The following input terminals/connectors must be connected to the end-product supply neutral: CON3
- The following end-product enclosures are required: Mechanical, , Fire, and , Electrical
- The following Production-Line tests are conducted for this product: Earthing Continuity, , Electric Strength
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): Platform: L1-L5, L7, L8, L12, L13, PFC Inductor, T1 and T3 (Class F, 155°C); Control Board: L15 and T1 (Class F, 155°C)
- The following components require special consideration during end-product Thermal (Heating) tests due to the indicated maximum temperature measurements during component-level testing: Power Supply Baseplate (85°C)

Additional Information

The clearance distances have additionally been assessed for suitability up to 3048 m elevation (1.15 correction factor as per IEC 60664-1, Table A2).

Issue Date: 2012-05-07 Page 5 of 28 Report Reference # E139109-A90-UL

Power supply is designed with a base plate that acts as a heat sink to all the power supply components; as a result, the actual component temperatures are based upon the relative temperature rise from the base plate temperature. Based upon this design, the base plate temperature should not exceed 85°C to insure component temperatures do not exceed their limits.

Nameplate Marking label provided is considered representative of all models.

Additional Standards

The product fulfills the requirements of: CSA C22.2 No. 60950-1-07 + A1:2011, , EN 60950-1:2006 + A1:2010 + A11:2009 + A12:2011, IEC 60950-1:2005 + A1:2009, UL 60950-1 2nd Ed. Revised 2011-12-19

Markings and instructions

Clause Title	Marking or Instruction Details
Power rating - Ratings	Ratings (voltage, frequency/dc, current)
Power rating - Company identification	Listee's or Recognized company's name, Trade Name, Trademark or File Number
Power rating - Model	Model Number
Fuses - Non-operator access/soldered-in fuses	Unambiguous reference to service documentation for instructions for replacement of fuses replaceable only by service personnel
Terminal for main protective earthing	Provided adjacent to the main protective earthing terminal (60417-5019)
Terminals for external primary power supply conductors	Capital letter "N" located adjacent to a terminal intended exclusively for connection of the primary power neutral conductor

Special Instructions to UL Representative

Units provided with optional fuse, FS2, should also be provided with the "CAUTION: Double pole/neutral fusing". The marking is not required for single pole fused units.

Issue Date: 2012-05-07 Page 6 of 28 Report Reference # E139109-A90-UL

Production-l	Production-Line Testing Requirements										
Electric Strength Test Special Constructions - Refer to Generic Inspection Instructions, Part AC for											
further infor	mation.										
		Removable		V		Test Time,					
Model	Component	Parts	Test probe location	rms	V dc	s					
All Models	Transformer, T1	-	Primary to Secondary	300	4242	1					
				0							
Earthing Co	ntinuity Test Exem	ptions - This	test is not required for th	e followi	ng models:						
Electric Stre	ngth Test Exemption	ons - This tes	t is not required for the f	ollowing	models:						
			ns - The following solid- uitry during the performa			ay be					
Sample and	Sample and Test Specifics for Follow-Up Tests at UL										
						Test					
Model	Component	Material	Test	Sa	ample(s)	Specifics					
N/A											

Issue Date: 2012-05-07 Page 7 of 28 Report Reference # E139109-A90-UL

1.5.1	TABLE: list of critical components							
Object/part or Description	Manufacturer/ trademark	type/model	technical data	Product Category CCN(s)	Required Marks of Conformity	Supplement ID		
Cover	Various	Various	Steel. Overall approx. 21.5 by 10 by 4.1 cm, min. 1 mm thick. Provided with numerous slot openings. Secured to Baseplate using screws. See Enclosure 4-20 for details	-	-			
Baseplate	Various	Various	Aluminum. Overall approx.21.5 by 10.3 cm by 6 mm thick	-	-			
Printed Wiring Board – Input Main Board	Various	Various	Overall 21 by 3.9 cm. Rated min. V-1, 130°C (rated for direct support of live parts). Secured to Baseplate using screws.	ZMPV2	UL			
Input Main Board - Primary Connector (CON 3)	AMP/TYCO	1-350943-0	Rated min 10A, 250V, min. 105°C. Pins secured through PWB by screws and soldered.	ECBT2 (E28476)	UL			
Input Main Board - Fuse (FS1)	Littelfuse	216 Series (0216010XEP)	Rated 10A, min. 250V, min. 105°C. Mounted horizontally with leads soldered through Main PWB.	JDYX2, JDYX8 (E10480)	UL, cUL			
Input Main Board - Fuse (FS1)- Alternate	Bel Fuse Inc	5HFP Series (5HFP10-R)	Rated 10A, min. 250V, min. 105°C. Mounted horizontally with leads soldered through Main PWB	JDYX2 (E20624)	UL, cUL			
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59	Xiamen Faratronic	MKP62 Series (Type C42)	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2, FOWX8 (E186600)	UL, cUL			
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59) - Alternate	Epcos/Siemens	B3292 Series	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2, FOWX8 (E97863)	UL, cUL			

Issue Date: 2012-05-07 Page 8 of 28 Report Reference # E139109-A90-UL

	T			T	1
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59) - Alternate	Vishay	F1778 Series	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2, FOWX8 (E112471)	UL, cUL
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59) - Alternate	Vishay	MKP 339 Series (2222 339 24105)	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2, FOWX8 (E112471)	UL, cUL
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59) - Alternate	Shiny Space	SX1 Series	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2, FOWX8 (E186561)	UL, cUL
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59) - Alternate	Xiamen Faratronic	MKP62 Series (Type C42)	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2, FOWX8 (E186600)	UL, cUL
Input Main Board - X- Capacitors (C6,C7,C9,C10,C58,C59) - Alternate	Yuon Yu Electronics Co. (Winday)	MPX Series	Rated max. 2.2 uF, min. 250V, marked "X2".	FOWX2 (E200119)	UL
Input Main Board - Insulator Sheet – X- Capacitors (C6,C7)	3M	1218	Two layers provided on side and top of capacitor body, min. 0.076 mm thick.	OANZ2 (E17385)	UL
Input Main Board - Relay (RL1)	Omron	G5Q Series (G5Q-14 DC24)	Rated min. 24V, 10A (Not relied upon for isolation)	NRNT2 (E41515)	UL
Input Main Board - Y- Capacitors (C12,C14,C55)	Murata	KH Series	Rated max. 4700 PF, min. 250V, marked "Y2".	FOWX2 (E37921)	
Input Main Board - Y- Capacitors (C12,C14,C55) - Alternate	Panasonic	TS Series	Rated max. 4700 PF, min. 250V, marked "Y2".	FOWX2 (E62674)	UL
Input Main Board - Y- Capacitors (C12,C14,C55) - Alternate	Vishay	WYO or WKO Series	Rated max. 4700 PF, min. 250V, marked "Y2".	FOWX2, FOWX8 (E183844)	UL, cUL

Issue Date: 2012-05-07 Page 9 of 28 Report Reference # E139109-A90-UL

Input Main Board - Y- Capacitors	TDK (TDK-EPC)	CS Series	Rated max. 4700 PF, min. 250V, marked "Y2".	FOWX2 (E37861)	UL
(C12,C14,C55) - Alternate					
Input Main Board - Y- Capacitors (C70,C71)	Murata	KH Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2 (E37921)	UL
Input Main Board - Y- Capacitors (C70,C71) - Alternate	Panasonic	TS Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2 (E62674)	UL
Input Main Board - Y- Capacitors (C70,C71) - Alternate	Vishay	WYO Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2, FOWX8 (E183844)	UL, cUL
Input Main Board - Inductor (L4) (PRI)	XP Power	Various (100XXXXX, where X can be any number between 0 and 9. Construction of Inductor 10012258 represents the entire series)	Toroidal. Core: 2 provided, approx. 7.1 mm OD by 9.6 mm high. Winding: (OBWM2), Copper Magnet Wire, rated min. 105°C. Provided with Inductor Support. See Enclosure 4-01 for construction details. Secured to PWB by solder.	-	-
Input Main Board - Inductor Support for Inductor (L4)	Dupont	FR530 (Rynite)	Overall 16.87 by 27.7 mm by min. 0.7 mm thick. Rated V-0, min. 155°C.	QMFZ2 (E41938)	UL
Input Main Board - Inductor Support for Inductor (L4) - Alternate	Chevron Phillips Chemical Co	R-4-230BL (Ryton)	Overall 16.87 by 27.7 mm by min. 0.7 mm thick. Rated V-0, min. 155°C.	QMFZ2 (E54700)	UL
Input Main Board - Inductor (L1, L5, L12, L13) (PRI)	XP Power	Various (1000XXXX, where X can be any number between 0 and 9. Construction of Inductor 10009332	Toroidal. Winding: (OBWM2), Copper Magnet Wire, rated min. 105°C. See Enclosure 4- 02 for construction details. Secured to PWB and Baseplate using Clampbase Input Filter Cover.	-	_

Issue Date: 2012-05-07 Page 10 of 28 Report Reference # E139109-A90-UL

		represents the entire series)			
Input Main Board - Clampbase Input Filter Cover (Inductors L1, L5, L12, L13)	Dupont	FR530 (Rynite)	Overall 8.5 by 5.8 by 2.1 cm, min. 0.9 mm thick. Rated V-0, min. 155°C Completely Covers Inductors L1, L5, L12, L13.	QMFZ2 (E41938)	UL
Input Main Board - Gap Pad - Clampbase Input Filter Cover	Bergquist	GPV0-0.080-01- 0816	Rated V-0, min. 150°C, min. 2 mm thick. Provided between Inductors (Inputs 1A, 2, and 3) and Baseplate. See Enclosure 4-21 for details.	QMFZ2 (E59150)	-
Input Main Board - Gap Pad - Clampbase Input Filter Cover	Bergquist	GPV0-0.080-01- 0816	Rated V-0, min. 150°C, min. 2 mm thick. Provided between Inductor (Input 1B) and Baseplate. See Enclosure 4-21 for details.	QMFZ2 (E59150)	-
Input Main Board – Insulator Sheet - (Inductors L1, L5, L12, L13)	Dupont	Type HN	Kapton Film, rated V-0, min. 150°C, min. 0.075 mm thick. Provided between Gap Pads on Inductors L1, L5, L12, and L13 and Baseplate. See Enclosure 4-21 for details.	QMFZ2 (E39505)	UL
Thermistor (TH1) - Optional	Various	Various	PTC. Rated min. 240 V, min. 150°C, min. 7 ohm, lss min. 5 A (Not relied upon for safety).	-	-
Input Main Board - Thermistor (TH1) - Optional	Ametherm	SL15 Series (SL15 7R005)	Rated 25 Ohm, 3 A (Not relied upon for safety).	-	-
Input Main Board - Thermistor (TH1) - Optional	Epcos/ Siemens	B57237S0709M	NTC. Rated 16 ohm at 25°C, max. 4.0 A (Not relied for safety).	-	-
Input Main Board - Diode Bridge (BR1)	Shindengen America	D20XB or D25XB series	Rated Rev. voltage (rms) min. 600 V, 20A, min. 150°C (Provides 2500 Vac isolation, relied upon for Basic Insulation). Secured to	QQQX2 (E142422)	UL

Issue Date: 2012-05-07 Page 11 of 28 Report Reference # E139109-A90-UL

			Baseplate by screw.			
Input Main Board - Diode Bridge (BR1) - Alternate	Various	Various	Rated Rev. voltage (rms) min. 600 V, 20A, 150°C (Provides 2500 Vac isolation, relied upon for Basic Insulation). Secured to Baseplate by screw.	QQQX2	UL	
Input Main Board – Diode Bridge (BR1) - Insulating Sheet	Dupont	100HN	Kapton tape, overall 38 by 31 by min. 0.075mm thick. Provided between BR1 body and Baseplate.	QMFZ2 (E39505)	UL	
Input Main Board - Electrolytic Capacitor (C28)	Various	Various	Rated max. 220 uF, min. 50V, min. 105°C. Provided with integral pressure relief.	-	-	
Input Main Board – Inductor (L2) (PRI)	XP Power	Various (1000XXXX, where x can be any number between 0 and 9. Construction of Inductor 10010686 represents the entire series)	Toroidal. Core: Ferrite. Overall approx. 15.3 by 12 mm. Winding: Triple Insulated Wire, see Inductor (L2) – Triple Insulated Wire for details. Oriented Vertically provided with Mounting Base between PWB and Inductor body. See Enclosure 4-04 for construction details. Provided with Class F insulation system, see Inductor Insulation System for details.		-	
Input Main Board – Mounting Base - Inductor (L2)	Chevron Phillips Chemical Co	R-4-230BL	Overall 16.2 by 2 mm. Rated V- 0, min. 2 mm thick. Provided between Inductor (L2) and PWB. See Enclosure 4-04 for details.	QMFZ2 (E54700)	UL	
Input Main Board - Inductor (PFC)(PRI)	XP Power	Various (1000XXXX, where x can be any number between 0 and 9. Construction of	Open-type. Class F. see Inductor (PFC) – Insulation System for details. Overall approx. 41.6 by 30.2 by 26 mm. Core: Ferrite Core.	-	-	

Issue Date: 2012-05-07 Page 12 of 28 Report Reference # E139109-A90-UL

	VD D	Inductor 10009334 represents the entire series)	Bobbin: Overall approx. 32 O.D. by 18.5 mm, see Inductor (PFC) – Bobbin Material. Windings: Triple Insulated Wire, see Inductor (PFC) – Triple Insulated Wire for details. Provided with outerwrap, see Insulation System – Insulating Tape for details. Flying Leads provided with sleeving and tubing. See Sleeving/Tubing. Secured to Baseplate using PFC Clip, Foil Clamp, and screws. See Enclosure 4-03 for details.			
Input Main Board - Inductors (PFC and L2)(PRI) - Insulation System	XP Power	Class 155 (F)	Rated 155°C.	OBJY2 (E324960)	UL	
Input Main Board - Inductor (PFC and L2)(PRI) - Insulating Tape	ЗМ	92, 1205 or 1350F	Polyester film tape, min. 1.0 mils (0.025 mm) thick, rated min. 130°C	OANZ2 (E17385)	UL	
Input Main Board - Inductor (PFC)(PRI) - Bobbin Material - Alternate	DuPont	FR530 or FR530L	Rated min. V-0, min. 1 mm thick, 155°C.	QMFZ2 (E41938)	UL	
Input Main Board - Inductor (PFC)(PRI) - Triple Insulating Wire Input Main Board -	Great Leoflon Industrial Co., Ltd Kuo Kuang Electronic	TRW (F)	Reinforced Insulation. Rated 155°C, min. 600 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 6kV Dielectric test during component evaluation). Reinforced Insulation. Rated	OBJT2 (E211989) OBJT2 (E222087)	UL	

Issue Date: 2012-05-07 Page 13 of 28 Report Reference # E139109-A90-UL

Inductor (PFC)(PRI) - Triple Insulating Wire - Alternate	Wire Co., Ltd		155°C, min. 1000 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 7.5kVrms Dielectric test during component evaluation).			
PFC Clip – Inductor (PFC)	Various	Various (XP Power Part No. 10009345)	Tin Plated Copper, min. 1mm thick. See Enclosure 4-03 for details. Secures PFC Inductor to Baseplate.	-	-	
Top Washer – PFC Clip – Inductor (PFC)	Various	Aluminum	Overall 25 mm dia by 2 mm thick. Secures PFC foil to top of PFC Clip.	-	-	
Foil Clamp – Inductor (PFC)	Various	Various (XP Power Part No. 10009707)	Aluminum alloy, overall 16.5 mm dia. by 2 mm thick. Secures PFC Inductor foil to bottom of Baseplate.	-	-	
Input Main Board - FETS (TR1, TR2)	Various (ST Mircroelectronics)	Various (STW26NM60N)	Rated 600V, 20A min. 150°C. Secured to main PCB by solder. Secured to Baseplate using Metal Plate, 32.5 by 18.2 by 0.6mm thick and Screws. Provided with plastic support. See FET Support for details.	-	-	
Input Main Board - Diode (D1)	Various (Philips Semi)	Various (BYV29- 500)	Rated 500V, 9A. Secured to Baseplate using Metal Plate, 32.5 by 18.2 by 0.6mm thick and Screws.	-	-	
Input Main Board - Diode and FET Support – FETS (D1,TR1, TR2)	Chevron Phillips Chemical Co	R-4-230BL	Rated V-0, overall approx. 48.5 by 20.4 by min. 2 mm thick. Provided between Diode (D1), FETs (TR1, TR2) and PWB.	QMFZ2 (E54700)	UL	
Input Main Board – FETS (D1,TR1, TR2) - Insulating Sheet	Variousq	Various	Natural Mica, Rated V-0, overall approx. 52.5 by 34 by min. 0.15 mm thick. Provided between Diode (D1), FETs (TR1, TR2) and PWB. See	-	-	

Issue Date: 2012-05-07 Page 14 of 28 Report Reference # E139109-A90-UL

			Enclosure for details.			
Input Main Board –	Various (Hitachi AIC	Various	Rated 450V, 560uF, min.	-	-	
Electrolytic Capacitor (C5)	Inc)	(HU42W561MRA S7PEPF)	105°C. Provided with integral pressure relief. Provided with Capacitor Insulator.			
Input Main Board – Capacitor Insulator (C5)	Chevron Phillips Chemical Co	R-4-230BL (Ryton)	Rated V-0, min. 200°C.Overall 52.5 by 39 by 38.5 mm, min. 1.25 mm thick. Provided between Capacitor (C5) body bottom and side and Baseplate	QMFZ2 (E54700)	UL	
Input Main Board – Electrolytic Capacitor (C22)	Various	Various	Rated 35V, 47uF, min. 105°C. Provided with integral pressure relief. Provided with Capacitor Insulator.	-	-	
Input Main Board – Electrolytic Capacitor (C25)	Various	Various	Rated 63V, 18uF, min. 105°C. Provided with integral pressure relief. Provided with Capacitor Insulator.	-	-	
Input Main Board – Electrolytic Capacitor (C28)	Various	Various	Rated 50V, 220uF, min. 105°C. Provided with integral pressure relief. Provided with Capacitor Insulator.	-	-	
Printed Wiring Board - Standby Board	Various	Various	Overall approx. 9 by 6.5 cm. Rated min. V-1, 130°C (rated for direct support of live parts). Secured to Output Board by solder. Provided with three flying lead wires, 26 AWG completely sleeved. See Insulating Tubing/Sleeving. Lead wires (FL1 to FL3) soldered to Input Main Board. Provided with Flying Lead Support. See Enclosure 5-02 for details	ZMPV2	UL	
Standby Board - Optical	Lite On	LTV-816 Series	Double protection, isolation	FPQU2, FPQU8	UL, cUL	

Issue Date: 2012-05-07 Page 15 of 28 Report Reference # E139109-A90-UL

Isolator (OPT1)	Semiconductor		voltage 5000 V	(E113898)		
Standby Board – Optical Isolator (OPT1) - Alternate	Renesas (NEC)	PS2561 Series	Double protection, isolation voltage 5000 V	FPQU2 (E72422)	UL	
Standby Board – Electrolytic Capacitor (C76)	Various	Various	Rated max. 47uF, min. 35V, 105°C. Provided with integral pressure relief.	-	-	
Standby Board – Bridging Capacitor (C17)	Murata	KH Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2 (E37921)	UL	
Standby Board – Bridging Capacitor (C17) - Alternate	Panasonic	TS Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2 (E62674)	UL	
Standby Board – Bridging Capacitor (C17) - Alternate	Vishay	WYO or WKO Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2, FOWX8 (E183844)	UL, cUL	
Standby Board – Electrolytic Capacitor (C20)	Various	Various	Rated max. 100uF, min. 35V, 105°C. Provided with integral pressure relief.	-	-	
Standby Board – Transformer (T1)	XP Power	1000XXXX, where X can be any number between 0 and 9. Constructional of transformer 10009330 represents the entire series	Open-type. Class F, see Transformer (T1) – Insulation System for details. Overall approx. 20.5 by 20.2 by 15.4 mm. Bobbin: Overall approx. 14.1 by 12.6 by 12.6 mm, min. 1.0 mm thick, see Transformer (T1) – Bobbin Material. Primary Windings: (OBWM2), Copper Magnetic Wire, rated min. 155°C. Secondary Windings: Triple Insulated Wire, see Transformer (T1) – Triple Insulated Wire for details. Provided with outerwrap, see Insulation System – Insulating			

Issue Date: 2012-05-07 Page 16 of 28 Report Reference # E139109-A90-UL

			Tape for details. See Enclosure 4-19 for details.			
Standby Board – Transformer (T1)(PRI) - Insulation System	XP Power	Class 155 (F)	Rated 155°C.	OBJY2 (E324960)	UL	
Standby Board – Transformer (T1) - Bobbin Material - Alternate	Sumitomo Bakelite Co., Ltd.	PM-9820 or PM- 9630 or T375J	Rated V-0, min. 1 mm thick, 150°C.	QMFZ2 (E41429)	UL	
Standby Board – Transformer (T1) - Triple Insulating Wire	Great Leoflon Industrial Co., Ltd	TRW (F)	Reinforced Insulation. Rated 155°C, min. 600 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 6kV Dielectric test during component evaluation).	OBJT2 (E211989)	UL	
Standby Board – Transformer (T1) - Triple Insulating Wire - Alternate	Kuo Kuang Electronic Wire Co., Ltd	REFU-F	Reinforced Insulation. Rated 155°C, min. 1000 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 7.5kVrms Dielectric test during component evaluation).	OBJT2 (E222087)	UL	
Standby Board – Transformer (T1) - Outerwrap	3M Corporation	1350F	Polyester film tape, min. 0.25 mm thick	OANZ2 (E17385)	UL	
Standby Board – Transformer (T1) - Insulating Tubing/Sleeving	Sumitomo	Sumitube F32 or B2	Rated min. 600 V, min. 125°C, VW-1, min. 0.4 mm thick.	YDPU2, YDPU8 (E48762)	-	
Standby Board – Electrolytic Capacitor (C36)	Various	Various	Rated max. 1000uF, min. 16V, 105°C. Provided with integral pressure relief.	-	Evaluated as part of this investigation	
Standby Board – Electrolytic Capacitor (C7)	Various	Various	Rated max. 180uF, min. 50V, 105°C. Provided with integral pressure relief.	-	Evaluated as part of this investigation	
Standby Board – Electrolytic Capacitor	Various	Various	Rated max. 220uF, min. 35V, 105°C. Provided with integral	-	Evaluated as part of this	

Issue Date: 2012-05-07 Page 17 of 28 Report Reference # E139109-A90-UL

(C58)			pressure relief.		investigation	
Standby Board – CON1	Various (Molex Inc)	Various (87833 Series)	Rated min. 125 Vac, 2 A. Copper alloy pins housed in bodies of QMFZ2, rated min. V-2.	ECBT2 (E29179)	UL	
Standby Board – CON2	Various	Various	Rated min. 250 Vac, 1 A. Copper alloy pins housed in bodies of QMFZ2, rated min. V-2.	Listed or ECBT2 or QMFZ2	UL	
Printed Wiring Board – Output Board	Various	Various	Overall 21 by 3.9 cm. Rated min. V-1, 130°C (rated for direct support of live parts). Secured to Baseplate using screws.	ZMPV2	UL	
Output Board - Y- Capacitors (C90,C91)	Murata	KH Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2 (E37921)	UL	
Output Board - Y- Capacitors (C90,C91) - Alternate	Panasonic	TS Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2 (E62674)	UL	
Output Board - Y- Capacitors (C90,C91) (PRI) - Alternate	Vishay	WYO Series	Rated max. 1000 PF, min. 250V, marked "Y2".	FOWX2, FOWX8 (E183844)	UL, cUL	
Output Board - FETS (TR4, TR5)	Various (Vishay or Internation Rectifier)	Various (IRFP460PBF)	Rated 500V, 20A min. 150°C. Secured to Output Board by solder. Secured to Baseplate using metal screws, 32.5 by 18.2 by 0.6mm thick and . Provided with plastic support. See FET Support for details.	-	Evaluated as part of this investigation	
Output Board - FETS (TR4, TR5) - Insulator Sheet	Various	Various	Natural Mica, Rated V-0, overall approx. 52.5 by 34 by min. 0.15 mm thick. Provided between FETs TR4,TR5, and PWB.	-	Evaluated as part of this investigation	
Output Board – Resistor (R31)	Various	Various	Rated 100 ohm. Secured to Baseplate using Metal Plate, 32.5 by 18.2 by 0.6mm thick	-	-	

Issue Date: 2012-05-07 Page 18 of 28 Report Reference # E139109-A90-UL

Output Board – FET and Resistor Support Output Board – FET and Resistor Support -	Dupont Chevron Phillips Chemical Co	FR530 (Rynite) R-4-230BL (Ryton)	and Screws. Provided with plastic support. See Resistor Support for details. Provided on FETs (TR4,TR5) and Resistor (R31). Overall 34.5 by 17 mm by min. 0.7 mm thick. Rated V-0, min. 155°C. Provided on FETs (TR\$,TR5) and Resistor (R31). Overall	QMFZ2 (E41938) QMFZ2 (E54700)	UL	
Alternate			34.5 by 17 mm by min. 0.7 mm thick. Rated V-0, min. 155°C.			
Output Board - Capacitor (C15, C16)	Various (Faratronic)	Various (C222G105K90C 00)	Rated 400V, 1uF.	-	-	
Output Board – Inductor (L3)	XP Power	Various (1000XXXX, where x can be any number between 0 and 9. Construction of Inductor 10010684 represents the entire series)	Toroidal. Core: Ferrite. Overall approx. 23.4 by 8.7 mm. Winding: Triple Insulated Wire, see Inductor (L3) – Triple Insulated Wire for details. Oriented Vertically provided with Mounting Base between PWB and Inductor body. See Enclosure 4-05 for construction details. Provided with Class F insulation system, see Inductor Insulation System for details.	-	-	
Output Board – Current/Drive Transformer (T3)	XP Power	Various (1000XXXX, where x can be any number between 0 and 9. Construction of Inductor 10009329 represents the entire series)	Toroidal. Class F, see Current/Drive Transformer (T3) - Insulation System for details. Core: Ferrite. Two provided, each overall approx. 12.4 mm OD by 6.7 mm wide. Secured to Printed Wiring Board using Carrier, See Carrier for details. See Enclosure 4-18 for construction details.	-	-	

Issue Date: 2012-05-07 Page 19 of 28 Report Reference # E139109-A90-UL

Output Board – Carrier -	Chevron Phillips	R-4-230BL	Overall 28.1 by 6.4 mm by min.	QMFZ2 (E54700)	UL	
Currrent/Drive	Chemical Co	(Ryton)	0.7 mm thick. Rated V-0, min.	QIVII 22 (L34700)	OL	
Transformer (T3)	Official do	(Itytori)	155°C.			
Output Board -	XP Power	Class 155 (F)	Rated 155°C.	OBJY2 (E324960)	UI	
Current/Drive	7 1 00.	0.000 100 (1)	1.4.64 1.65 6.	(2021000)	02	
Transformer (T3) -						
Insulation System						
Output Board -	Great Leoflon	TRW (F)	Reinforced Insulation, Rated	OBJT2 (E211989)	UL	
Current/Drive	Industrial Co., Ltd	1100 (1)	155°C, min. 600 Vpk, min. 4.5	00012 (2211000)	02	
Transformer (T3) - Triple	mademar Go., Eta		mil total nominal insulation			
Insulating Wire			thickness (Passed 6kV			
mediaming vine			Dielectric test during			
			component evaluation).			
Output Board -	Kuo Kuang Electronic	RFFU-F	Reinforced Insulation. Rated	OBJT2 (E222087)	UL	
Current/Drive	Wire Co., Ltd		155°C, min. 1000 Vpk, min. 4.5	05012 (2222001)	02	
Transformer (T3) - Triple	Will 6 661, 216		mil total nominal insulation			
Insulating Wire -			thickness (Passed 7.5kVrms			
Alternate			Dielectric test during			
			component evaluation).			
Output Board -	XP Power	Various	Open-type. Class F, see	-	-	
Transformer (T1)		(1000XXXX,	Transformer (T1) – Insulation			
,		where x can be	System for details.			
		any number	Overall approx. 41.6 by 30.2 by			
		between 0 and 9.	26 mm.			
		Construction of	Core: Ferrite Core.			
		Inductor	Bobbin: Overall approx. 32			
		10009306	O.D. by 18.5 mm, see			
		represents the	Transformer (T1) – Bobbin			
		entire series)	Material.			
		,	Windings: Triple Insulated Wire,			
			see Transformer (T1) - Triple			
			Insulated Wire for details.			
			Provided with outerwrap, see			
			Insulation System – Insulating			
			Tape for details.			
			Flying Leads provided with			

Issue Date: 2012-05-07 Page 20 of 28 Report Reference # E139109-A90-UL

			sleeving and tubing. See Sleeving/Tubing. Secured to Baseplate using Transformer (T1) Clip, Foil Clamp, and screws. See Enclosure 4-14 to 4-17 for details.			
Output Board – Transformer (T1) - Insulation System	XP Power	Class 155 (F)	Rated 155°C.	OBJY2 (E324960)	UL	
Output Board – Transformer (T1) - Insulating Tape	3M	92, 1205 or 1350F	Polyester film tape, min. 1.0 mils (0.025 mm) thick, rated min. 130°C	OANZ2 (E17385)	UL	
Output Board – Transformer (T1) - Bobbin Material	DuPont	FR530 or FR530L	Rated min. V-0, min. 1 mm thick, 155°C.	QMFZ2 (E41938)	UL	
Output Board – Transformer (T1) - Triple Insulating Wire	Great Leoflon Industrial Co., Ltd	TRW (F)	Reinforced Insulation. Rated 155°C, min. 600 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 6kV Dielectric test during component evaluation).	OBJT2 (E211989)	UL	
Output Board – Transformer (T1) - Triple Insulating Wire - Alternate	Kuo Kuang Electronic Wire Co., Ltd		Reinforced Insulation. Rated 155°C, min. 1000 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 7.5kVrms Dielectric test during component evaluation).	OBJT2 (E222087)	UL	
Output Board - Transformer Clip – Transformer (T1)	Various	Various (XP Power Part No. 10009344)	Tin Plated Copper, min. 1mm thick. See Enclosure 4-14 to 4-17 for details. Secures PFC Inductor to Baseplate.	-	-	
Output Board -Top Washer – Transformer (T1)	Various	Aluminum	Overall 25 mm dia by 2 mm thick. Secures PFC foil to top of PFC Clip.	-	-	
Output Board -Foil	Various	Various (XP	Aluminum alloy, overall 16.5	-	-	

Issue Date: 2012-05-07 Page 21 of 28 Report Reference # E139109-A90-UL

r	T	T	T	1		
Clamp - Transformer		Power Part No.	mm dia. by 2 mm thick.			
(T1)		10009707)	Secures PFC Inductor foil to			
			bottom of Baseplate.			
Output Board – Bridging	Array Electronics	10004629	Rated max. 1000 pF, min. 250	-	-	
Capacitor (C33) (PRI -			V, marked with "Y1".			
SEC)			,			
Output Board – Bridging	Kemet Electronics	ERP (ERP610	Rated max. 1000 pF, min. 250	FOWX2, FOWX8	UL	
Capacitor (C33) (PRI -	OY (Evox Rifa)	Series)	V, marked with "Y1".	(E73869)		
SEC) - Alternate	,	,		,		
Output Board – Bridging	Murata Mfg Co Ltd	KX Series	Rated max. 1000 pF, min. 250	FOWX2, FOWX8	UL, cUL	
Capacitor (C33) (PRI -			V, marked with "Y1".	(E37921)	,	
SEC) - Alternate				(===:)		
Output Board – Bridging	TDK-EPC Corp	CD Series	Rated max. 1000 pF, min. 250	FOWX2,	UL, cUL	
Capacitor (C33) (PRI -	•		V, marked with "Y1".	(E37861)		
SEC) - Alternate				,		
Output Board – Bridging	Vishay Electronic	VKP or VY1	Rated max. 1000 pF, min. 250	FOWX2, FOWX8	UL, cUL	
Capacitor (C33) (PRI -	GMBH	Series	V, marked with "Y1".	(E183844)		
SEC) - Alternate				,		
Output Board –	Various	Various	Rated max. 150 uF, min. 63V,	-	-	
Electrolytic Capacitor			min. 105°C. Provided with			
(C32)			integral pressure relief.			
Thermistor (TH1) -	Vishay	NTCLE203E3472	NTC. Rated min. 240 V, min.	XGPU2 (E14885)	UL	
Optional		FB0Series	150°C, min. 4.7k ohm, Iss min.			
			5 A (Not relied upon for safety).			
			Secured to bottom of Baseplate			
			near Transfromer T1.			
Output Board – Resistor	Various	Various	Rated 4.7 ohm. Secured to	-	-	
(R32)			Baseplate using Metal Plate,			
			58.7 by 18.2 by 0.6mm thick			
			and Screws. Provided with			
			plastic support. See Resistor			
			Support for details.			
Output Board – Diodes	Various (Shindengen	Various	Rated Rev. voltage (rms) min.	-	-	
(D2 – D4)	America Inc)	(S60SC6MT-	60V, 60A, min. 150°C. Secured			
		5000)	to Output Board by solder.			
			Secured to Baseplate using			

Issue Date: 2012-05-07 Page 22 of 28 Report Reference # E139109-A90-UL

			Metal Plate, 58.7 by 18.2 by 0.6mm thick and Screws. Provided with plastic support. See Diode Support for details.			
Output Board – Resistor (R32) and Diodes (D2 – D4) Support	Chevron Phillips Chemical Co	R-4-230BL	Rated V-0, overall approx. 61.5 by 4.2 by min. 0.7 mm thick. Provided between Resistor (R32) and Diodes (D2 – D4) and PWB.	QMFZ2 (E54700)	UL	
Output Board – Inductor (L7)	XP Power	Various (1000XXXX, where x can be any number between 0 and 9. Construction of Inductor 10009307 represents the entire series)	Open-type. Overall approx. 37 by 24.5 by 24.4 mm. Core: Ferrite Core. Bobbin: Overall approx. 25.7 O.D. by 15.2 mm, see Inductor (L7) – Bobbin Material. Windings: Copper foil, Winding W1a, 3 turns; Winding W1b, 5 turns. Provided with outerwrap,. Flying Leads provided with sleeving and tubing. See Sleeving/Tubing. Secured to Baseplate using Clip, Foil Clamp, and screws. See Enclosure 4-06 to 4-09 for details.	-	-	
Output Board – Inductor (L7) – Alternate	XP Power	Various (1000XXXX, where x can be any number between 0 and 9. Construction of Inductor 10009313 represents the entire series)	Open-type. Overall approx. 37 by 24.5 by 24.4 mm. Core: Ferrite Core. Bobbin: Overall approx. 25.7 O.D. by 15.2 mm, see Inductor (L7) – Bobbin Material. (OBWM2), Copper Magnet Wire, rated min. 105°C Provided with Copper foil and		-	

Issue Date: 2012-05-07 Page 23 of 28 Report Reference # E139109-A90-UL

Output Board – Inductor	ЗМ	92, 1205 or 1350F		OANZ2 (E17385)	UL	
(L7) - Insulating Tape Output Board – Inductor	Ideal Tape	IT-7170	mils (0.025 mm) thick, rated min. 130°C Polyester film tape, min. 1.0	OANZ2 (E82910)	UL	
(L7) - Insulating Tape – Alternate	Charman Dhilling	R-4-230BL	mils (0.025 mm) thick, rated min. 130°C Rated min. V-0, min. 1 mm	ONETO (EF 4700)	UL	
Output Board – Inductor (L7) - Bobbin Material	Chevron Phillips Chemical Co	(Ryton)	thick, 200°C.	QMFZ2 (E54700)		
Output Board – Inductor (L7) - Bobbin Material - Alternate	DuPont	FR530 or FR530L	Rated min. V-0, min. 1 mm thick, 155°C.	QMFZ2 (E41938)	UL	
Output Board – Inductor (L7) - Triple Insulating Wire	Great Leoflon Industrial Co., Ltd	TRW (F)	Reinforced Insulation. Rated 155°C, min. 600 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 6kV Dielectric test during component evaluation).	OBJT2 (E211989)	UL	
Output Board – Inductor (L7)- Triple Insulating Wire - Alternate	Kuo Kuang Electronic Wire Co., Ltd		Reinforced Insulation. Rated 155°C, min. 1000 Vpk, min. 4.5 mil total nominal insulation thickness (Passed 7.5kVrms Dielectric test during component evaluation).	OBJT2 (E222087)	UL	
Output Board – Inductor (L7) - Clip	Various	Various (XP Power Part No. 10009346)	Tin Plated Copper, min. 1mm thick. See Enclosure 4-06 to 4-09 for details. Secures Inductor L7 to Baseplate.	-	-	
Output Board – Inductor	Various	Aluminum	Overall half moon shaped, 20.8	-	-	

Issue Date: 2012-05-07 Page 24 of 28 Report Reference # E139109-A90-UL

(L7) - Top Washer -Clip			mm dia by 2 mm thick.			
- Inductor (PFC)			Secures PFC foil to top of PFC			
madotor (1 1 O)			Clip.			
Output Board - Inductor	Various	Various (XP	Aluminum alloy, overall 16.5	-	-	
(L7) - Foil Clamp		Power Part No.	mm dia. by 2 mm thick.			
		10009707)	Secures PFC Inductor foil to			
		,	bottom of Baseplate.			
Output Board – Y-	Murata	KY Series	Rated max. 470 PF, min. 250V,	FOWX2 (E37921)	UL	
Capacitors (C11)			marked "Y2".			
Output Board – Y-	Panasonic	TS Series	Rated max. 470 PF, min. 250V,	FOWX2 (E62674)	UL	
Capacitors (C11) -			marked "Y2".			
Alternate						
Output Board – Y-	Vishay	WYO or WKO	Rated max. 470 PF, min. 250V,	FOWX2, FOWX8	UL, cUL	
Capacitors (C11) -		Series	marked "Y2".	(E183844)		
Alternate						
Output Board – Y-	TDK (TDK-EPC)	CS Series	Rated max. 470 PF, min. 250V,	FOWX2 (E37861)	UL	
Capacitors (C11) -			marked "Y2".			
Alternate						
Output Board – Y-	Murata	KH Series	Rated max. 4700 PF, min.	FOWX2 (E37921)	UL	
Capacitors			250V, marked "Y2".			
(C80,C81,C82)						
Output Board – Y-	Panasonic	TS Series	Rated max. 4700 PF, min.	FOWX2 (E62674)	UL	
Capacitors			250V, marked "Y2".			
(C80,C81,C82) -						
Alternate						
Output Board – Y-	Vishay	WYO or WKO	Rated max. 4700 PF, min.	FOWX2, FOWX8	UL, cUL	
Capacitors		Series	250V, marked "Y2".	(E183844)		
(C80,C81,C82) -						
Alternate						
Output Board – Y-	TDK (TDK-EPC)	CS Series	Rated max. 4700 PF, min.	FOWX2 (E37861)	UL	
Capacitors			250V, marked "Y2".			
(C80,C81,C82) -						
Alternate						
Output Board –	Various	Various	Rated 63V, 18uF, min. 105°C.	-	-	
Electrolytic Capacitor			Provided with integral pressure			
(C54)			relief. Provided with Capacitor			

Issue Date: 2012-05-07 Page 25 of 28 Report Reference # E139109-A90-UL

			Insulator.			
Output Board – Electrolytic Capacitor (C4)	Various	Various	Rated 16V, 1800uF, min. 105°C. Provided with integral pressure relief. Provided with Capacitor Insulator.	-	-	
Output Board – Electrolytic Capacitor (C4)	Various (ST Microelectronics)	Various (STW26NM60N)	Rated 16V, 22000uF, min. 105°C. Provided with integral pressure relief. Provided with Capacitor Insulator.	-	-	
Output Board – Busbar Assembly – 12V Models only	Various	Various	Three provided. Copper alloy, L-shapped, overall approx. 70 by 38.5, 2 mm thick. Soldered to Transformer (T1) and secured to Output Board by solder. Provided with plastic busbar suppor. See Bus Bar Support for material. Secured to bottom of Baseplate by a screw. See Enclosure 4-21 for details.		-	
Output Board – Bus Bar Assembly – 12V Models only – Bus Bar Support	Chevron Phillips Chemical Co	R-4-230BL (Ryton)	Rated min. V-0, min. 1 mm thick, 200°C.	QMFZ2 (E54700)	UL	
Output Board – Bus Bar Assembly – 12V Models only – Bus Bar Support - Alternate	DuPont	FR530 or FR530L	Rated min. V-0, min. 1 mm thick, 155°C.	QMFZ2 (E41938)	UL	
Output Board – Output Bus Bar	Various	Various	Copper alloy, overall approx. 47 by 14 by 2 mm thick. Secured to Output Board by solder.	-	-	
Output Board - Output Bus	Various	Various	S-shaped, copper alloy, overall approx. 61.6 by 15 by 2 mm thick. Secured to Output Board (SMD side) by solder and screws.	-	-	
Output Board – Terminal	various	Various	U-shaped, Copper alloy, overall	1 -	-	

Issue Date: 2012-05-07 Page 26 of 28 Report Reference # E139109-A90-UL

Outputs (CON1, CON2)			approx. 12.9 by 11.6 by 2 mm thick. Secured to Output Board by solder.			
RTV	Nominative Performance Materials	RTV-128	Rated min. HB, min. 105°C	QMFZ2 (E36952)	UL	
RTV - Alternate	Various	Various	Rated min. HB, min. 105°C	QMFZ2	UL	
Insulating Sleeving/ Tubing	Various	Various	Rated 300V min., 125°C, min. VW-1, min. 0.4 mm thick.	YDPU2	UL	
Wire Positioning Device	Various	Various	Rated min. 110°C.	ZODZ2	UL	

Issue Date: 2012-05-07 Page 27 of 28 Report Reference # E139109-A90-UL

Enclosures

<u>Type</u>	Supplement Id	<u>Description</u>
Photographs	3-01	Model CCH400PSXX/CCH600PSXX - Top View
Photographs	3-02	Model CCH400PSXX/CCH600PSXX - Side Views
Photographs	3-03	Model CCH400PSXX/CCH600PSXX - Front and Rear View
Photographs	3-04	Model CCH400PSXX/CCH600PSXX - Internal Top View
Photographs	3-05	Model CCH400PSXX/CCH600PSXX - Internal PWB View
Photographs	3-06	Model CCH400PSXX/CCH600PSXX - Standby Board Top View
Photographs	3-07	Model CCH400PSXX/CCH600PSXX - Standby Board Bottom View
Diagrams	4-01	Model CCH400PSXX/CCH600PSXX - Inductor Assembly (L4)
Diagrams	4-02	Model CCH400PSXX/CCH600PSXX - Inductor Assembly (L1, L5, L12, L13)
Diagrams	4-03	Model CCH400PSXX/CCH600PSXX - Inductor (PFC)
Diagrams	4-04	Model CCH400PSXX/CCH600PSXX - Inductor (L2)
Diagrams	4-05	Model CCH400PSXX/CCH600PSXX - Inductor (L3)
Diagrams	4-06	Model CCH400PSXX/CCH600PSXX - Inductor (L7) 12V
Diagrams	4-07	Model CCH400PSXX/CCH600PSXX - Inductor (L7) 24V
Diagrams	4-08	Model CCH400PSXX/CCH600PSXX - Inductor (L7) 28V
Diagrams	4-09	Model CCH400PSXX/CCH600PSXX - Inductor (L7) 48V
Diagrams	4-10	Model CCH400PSXX/CCH600PSXX - Inductor (L8) 12V
Diagrams	4-11	Model CCH400PSXX/CCH600PSXX - Inductor (L8) 24V/28V
Diagrams	4-12	Model CCH400PSXX/CCH600PSXX - Inductor (L8) 48V
Diagrams	4-13	Model CCH400PSXX/CCH600PSXX - Standby Board Inductor (L15)
Diagrams	4-14	Model CCH400PSXX/CCH600PSXX - Transformer (T1) 12V
Diagrams	4-15	Model CCH400PSXX/CCH600PSXX - Transformer (T1) 24V
Diagrams	4-16	Model CCH400PSXX/CCH600PSXX - Transformer (T1) 28V
Diagrams	4-17	Model CCH400PSXX/CCH600PSXX - Transformer (T1) 48V
Diagrams	4-18	Model CCH400PSXX/CCH600PSXX - Transformer (T3)
Diagrams	4-19	Model CCH400PSXX/CCH600PSXX - Standby Board Transformer (T1)
Diagrams	4-20	Model CCH400PSXX/CCH600PSXX - Enclosure
Diagrams	4-21	Model CCH400PSXX/CCH600PSXX - Overall Mechanical Drawing
Schematics + PWB	5-01	Model CCH400PSXX/CCH600PSXX - Main PWB (Component/Trace Layout)
Schematics + PWB	5-02	Model CCH400PSXX/CCH600PSXX - Standby Board

Issue Date: 2012-05-07 Page 28 of 28 Report Reference # E139109-A90-UL

	(Component/Trace Layout)
Manuals	
Miscellaneous	